

Meeting Minutes Transmittal

Liquid Waste and Fuel Storage
 Project Managers Meeting
 825 Jadwin/Room 340
 Richland, Washington
 June 24, 2010

The undersigned indicate by their signatures that these meeting minutes reflect the actual occurrences of the above dated Project Managers Meeting. Signatures denote concurrence with the content only and are not intended to imply agreement to any commitments.

Frederick St Bond Date: 7-22-10
 Project Manager Representative, Ecology

SK Moy (Not @ Meeting) Date: 7-22-10
 Project Manager Representative, RL

Cathy D. Wood for D. Flyckt Date: 7/22/10
 Project Manager Representative, CHPRC

LWFS Administrative Record	H6-08
FW Bond	H0-57
HC Boynton	S5-31
KA Conaway	H0-57
DL Flyckt	T4-10
MR Kembel	S5-31
SK Moy	A6-38

RECEIVED
 JUL 30 2010

EDMC

LIQUID WASTE AND FUEL STORAGE
 Project Managers Meeting Minutes
 825 Jadwin/Room 340/700 Area
 Richland, Washington

June 24, 2010

I. Approval of April 29, 2010 Liquid Waste and Fuels Storage Project Manager Meeting Minutes (Ecology/DOE-RL/CHPRC).

A. Ecology approved the April 29 and February 25, 2010 minutes. Rick Bond (Ecology) made a correction to the April 29 minutes by crossing out the word “annual” that was repeated, and then initialed the change. Sen Moy’s (RL) signature will be obtained at a later time. Approval for the February minutes had been deferred until an update regarding the liquid level reported for Basin 44 in the December operational report could be inserted in the minutes. Paul Martin (CHPRC) read the update as follows: “Subsequent to the approval of the January 28, 2010 meeting minutes, a typographical error was discovered in the operation report for December 2009. The report indicated the liquid level in Basin 44 at the end of December was 29.1 feet. The correct level should have been 20.9 feet. The January 2010 meeting minutes were corrected prior to the submittal to the Administrative Record. The parties agreed to document the change via this note in the February PMM minutes.”

II. Operational Status

LERF Basin Liquid Level, Inventory and Waste Received April 2010			
	Basin 42	Basin 43	Basin 44
Basin Liquid Level and Inventory (as of 05/03/2010)	18.5 ft. and 5.78 Mgal	4.3 ft and 0.83 Mgal	21.1 ft and 7.15 Mgal
Received 3 tanker shipments from AdvanceMed during April		~1500 gallons*	
Received 38 tanker shipments from GW during April		~19,000 gallons*	
Received 20 tanker shipments from Modutank during April		~50,000 gallons*	
Received 2 tanker shipments of MWBT leachate during April		~14,000 gallons*	
Received 2 tanker shipments of DR5 pump & treat regen water in April			~5,000 gallons*

*Estimated volume was determined by multiplying the number of tankers received by a previously established tanker volume value that varies by tanker type.

Effluent Treatment Facility – Treated Basin 43 wastewater (~2.7 Mgal)
200 Area Treated Effluent Disposal Facility – receiving wastewater at ~612 gpm (based on 05/03/2010 96-hour total flow)
300 Area Treated Effluent Disposal Facility – discontinued operations
340 Complex – Nothing to report.

LERF Basin Liquid Level, Inventory and Waste Received in May 2010			
	Basin 42	Basin 43	Basin 44
Basin Liquid Level and Inventory (as of 06/1/2010)	19.1 ft. and 6.08 Mgal	8.3 ft and 1.79 Mgal	21.1 ft and 7.15 Mgal
Received in 4 tanker shipments from AdvanceMed during May		~2,000 gallons*	
Received 37 tanker shipments from GW during May		~18,500 gallons*	
Received 1 tanker shipment of MWBT leachate during May		~7,000 gallons*	
Received 2 tanker shipments of 100N wastewater during May			~8,000 gallons*

*Estimated volume was determined by multiplying the number of tankers received by a previously established tanker volume value that varies by tanker type.

Effluent Treatment Facility – Treated Basin 43 wastewater (~0.75 Mgal)
200 Area Treated Effluent Disposal Facility – receiving wastewater at ~1300 gpm (based on TEDF Flow Summary Datasheet)
300 Area Treated Effluent Disposal Facility – discontinued operations
340 Complex – Nothing to report.

III. Project Specific Issues

A. ETF/LERF Dangerous Waste Permit Status

Mr. Bond stated that the permit condition language for the additional well has been agreed upon with RL, and Doug Hildebrand concurred (RL). Mr. Bond added that he will be drafting text regarding the additional well to insert in the statement of basis. Tony Miskho (CHPRC) stated that he submitted the LERF groundwater permit modification to Suzette Thompson (MSA) for formatting, and it will be submitted to Ecology as a Class 3 permit modification.

B. 310/340 Status

There was no change in status to report. Operations have been discontinued.

C. ST4502 Permit Status

There was no status reported on the ST4502 permit.

D. ST4500 Permit Status
There was no status reported on the ST4500 permit.

IV. General Discussions

A. There were no topics for general discussion.

V. Status of Actions

B. There were no actions to status.

VI. New Action Items

A. There were no new actions identified.

VII. Documents for Submittal to the Administrative Record

A. There were no documents identified.

VIII. Next Project Managers Meeting

A. The next PMM was scheduled for July 22, 2010.

**LIQUID WASTE AND FUEL STORAGE
PROJECT MEETING
825 Jadwin/Room 340
Hanford, Washington
June 24, 2010**

9:30 a.m. to 10 a.m.

Agenda

- I. Approval April 29, 2010 Liquid Processing and Capsule Storage Project Meeting Minutes (Ecology/DOE-RL/CHPRC)
- II. Operational Status
- III. Project Specific Issues
 - A. ETF/LERF Dangerous Waste Permit Status
 - B. 310/340 Status
 - C. ST4502 Permit Status
 - D. ST4500 Permit Status
- IV. General Discussions
- V. Status of Actions
- VI. New Action Items
- VII. Documents for Submittal to the Administrative Record
- VIII. Next Project Managers Meeting

LERF Basin Liquid Level, Inventory and Waste Received			
	Basin 42	Basin 43	Basin 44
Basin Liquid Level and Inventory (as of 05/03/2010)	18.5 ft. and 5.78 Mgal	4.3 ft and 0.83 Mgal	21.1ft and 7.15 Mgal
Received 3 tanker shipments from AdvanceMed during April		~1,500 gallons *	
Received 38 tanker shipments from GW during April		~19,000 gallons *	
Received 20 Tanker Shipments from Modu-Tank during April		~50,000 gallons *	
Received 2 tanker shipments of MWBT Lechate during April.		~14,000 gallons *	
Received 2 tanker shipments of DR5 Pump & Treat Regen Water during April			~5,000 gallons *

* Estimated volume was determined by multiplying the number of tankers received by a previously established tanker volume that varies by tanker type

Effluent Treatment Facility – Treated Basin 43 wastewater (~2.7 Mgal)
200 Area Treated Effluent Disposal Facility – receiving wastewater at ~612 gpm (based on 05/03/2010 96-hour total flow)
300 Area Treated Effluent Disposal Facility –discontinued operations
340 Complex – Nothing to report.

LERF Basin Liquid Level, Inventory and Waste Received			
	Basin 42	Basin 43	Basin 44
Basin Liquid Level and Inventory (as of 06/01/2010)	19.1 ft. and 6.08 Mgal	8.3 ft and 1.79 Mgal	21.1ft and 7.15 Mgal
Received 4 tanker shipments from AdvanceMed during May		~2,000 gallons *	
Received 37 tanker shipments from GW during May		~18,500 gallons *	
Received 1 tanker shipment of MWBT Lechate during May		~7,000 gallons *	
Received 2 tanker shipments of 100 N Wastewater during May			~8,000 gallons *

* Estimated volume was determined by multiplying the number of tankers received by a previously established tanker volume that varies by tanker type

Effluent Treatment Facility – Treated Basin 43 wastewater (~0.75 Mgal)
200 Area Treated Effluent Disposal Facility – receiving wastewater at ~1300 gpm (based on TEDF Flow Summary Datasheet)
300 Area Treated Effluent Disposal Facility –discontinued operations
340 Complex – Nothing to report.

