

STAR 1



13333.2490


9405783

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

Mail Stop PV-11 • Olympia, Washington 98504-8711 • (206) 459-6000

November 16, 1994

Mr. James E. Rasmussen
Acting Program manager
Office of Environmental Assurance,
Permits, and Policy
U. S. Department of Energy
P. O. Box 550
Richland, WA 99352-0550



Dear Mr. Rasmussen:

We have received and reviewed your August 16, 1994, letter to Ms. Julie Atwood regarding compliance with the Uniform Fire Code for the storage of sodium from the Fast Flux Test Facility. Your letter requests two deviations from the Uniform Fire Code. One deviation you propose is the omission of a fire sprinkler system, which would apply water to the contents of the building proposed to store metallic sodium. The second deviation is to exceed tank volume limits for the sodium. Based upon the information provided in your letter and the results of a state Fire Marshall Office review (Attachment 1), Ecology approves your request for the two deviations from the Uniform Fire Code.


Ecology and possibly the state Fire Marshall Office, will review your design in more detail during the Dangerous Waste permitting process. Should you have any questions regarding this approval, please contact me at (206) 407-7132.

Sincerely,

Joseph J. Witczak, Supervisor
Regulatory and Technical Support Unit
Nuclear Waste Program

JJW:dr
Enclosure

cc: Mike Paddock, DCTED
R. G. Hastings, USDOE
Administrative Record, WHC



9513333.2491

CORRESPONDENCE DISTRIBUTION COVERSHEET

Author: J. J. Witczak, Ecology Addressee: J. E. Rasmussen, RL Correspondence No.: Incoming: 9405783

Subject: COMPLIANCE WITH THE UNIFORM FIRE CODE FOR THE STORAGE OF SODIUM
FROM THE FAST FLUX TEST FACILITY (FFTF)

INTERNAL DISTRIBUTION

Approval	Date	Name	Location	w/att
		Correspondence Control	A3-01	
		L. D. Arnold	B2-35	
		J. R. Bell	L6-51	
Sr. Staff/Assignee.....		R. J. Bliss	B3-04	
		D. M. Busche	L4-74	
		D. B. Cartmell	R3-56	
		W. T. Dixon	H6-21	
		D. E. Good	S3-97	
		P. J. Mackey	B3-15	
		J. C. Midgett	N2-51	
		S. R. Moreno	B3-06	
		M. M. Pelletier	R3-61	
		J. M. Roberts	A4-79	
		D. J. Swaim	B3-51	
		C. W. Walton	L4-01	
		EDMC	H6-08	
		Program Support Center	A2-18	

