



0071917

Department of Energy  
Richland Operations Office  
P.O. Box 550  
Richland, Washington 99352

07-AMCP-0074

DEC 22 2006

Ms. Debra McBaugh, Section Head  
Environmental Radiation Section  
Washington State Department of Health  
P.O. Box 47827  
Olympia, Washington 98504

Mr. David Grant  
Aquatic Resources Division  
State of Washington  
Department of Natural Resources  
713 East Bowers Road  
Ellensburg, Washington 98926

**RECEIVED**  
JAN 09 2007  
**EDMC**

Addressees:

DEPARTMENT OF NATURAL RESOURCES LAND LEASE MONITORING REPORT  
FOR NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT  
NO. WA 002591-7 OUTFALL 001 - NOVEMBER 2006

The purpose of this letter is to forward for your review, the attached 300 Area Treated Effluent Disposal Facility, Department of Natural Resources monthly monitoring data, as required by Aquatic Lands Sewer Outfall Lease 20-013357. Monthly monitoring data for radionuclides present in the effluent are provided in the attached table. The data indicate that all values monitored are well below State guidelines. Reporting of monthly composite sample results are provided and transmitted to the Washington State Department of Health, according to Exhibit C of the lease. This report covers the reporting period from October 24, 2006, through November 21, 2006.

If you have any questions, please contact me, or you may contact Mark French of my staff, on (509) 373-9863.

Sincerely,

Matthew S. McCormick, Assistant Manager  
for the Central Plateau

AMCP:OMH

Attachment

cc: See Page 2

Addressees  
07-AMCP-0074

-2-

DEC 22 2006

cc w/attach:

G. Bohnee, NPT

A. L. Boyd, EPA

K. A. Conaway, Ecology

R. H. Engelmann, DFSH

D. L. Halgren, FHI

S. Harris, CTUIR

R. Jim, YN

K. Ogle, EPA (Seattle)

M. Priddy, WDOH

D. G. Ranade, FHI

E. R. Skinnerland, Ecology

H. T. Tilden, PNNL

Administrative Record (300 Area Treated Effluent  
Disposal Facility Liquid Effluent) and (Aquatic  
Lands Sewer Outfall Lease 20-013357)  
Environmental Portal

Hanford Site  
300 Area Treated Effluent Disposal Facility

Monthly Monitoring Data

November 2006

Analysis	Result (pCi/L)	State Standard (pCi/L)
Total Alpha	BDL <sup>(2)</sup>	15 <sup>(3)</sup>
Total Beta	2.80	50 <sup>(3)</sup>
GEA <sup>(1)</sup> - <sup>60</sup> Co	BDL <sup>(2)</sup>	3,000 <sup>(4)</sup>
<sup>137</sup> Cs	BDL <sup>(2)</sup>	1,000 <sup>(4)</sup>
Tritium	96.0	20,000 <sup>(3)</sup>

- (1) GEA: Gamma Energy Analysis
- (2) BDL: Below Detection Limit
- (3) Standards for total alpha, total beta, and tritium from Department of Natural Resources Aquatic Resources Lease 20-013357
- (4) Washington Administrative Code 246-221-290 (Table II, effluent water)