

# START



0021634

Incoming:9203012

STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY

Mail Stop PV-11 • Olympia, Washington 98504-8711 • (206) 459-6000

May 11, 1992

Mr. Ron D. Izatt  
United States Department of Energy  
P.O. Box 550  
Richland, WA 99352

Re: 241-A Tank Farm Cooling Water Sampling and Analysis Plan

Dear Mr. Izatt:

I have reviewed the 241-A Tank Farm Cooling Water Sampling and Analysis Plan.  
I have the following comments:

1. Does the proportional sampler in the Condenser Building measure flow?  
If so, why not move this sampler downstream of the warm water sump so that flow and chemical constituents can be measured at the same time?  
If this is impossible, then some other method should be employed to measure discharge volume leaving the warm water sump.
2. Confirm that the sample bottle list on page 14 conforms to the list in 40 CFR 136.3.

If you have any questions about this letter, please call me at (206) 438-7558.

Sincerely,

Gary Anderson, P.E.  
Environmental Engineer 3  
Nuclear and Mixed Waste Management Program

GA:jw

- cc: Dan Duncan, EPA  
J.M.Hennig, DOE  
R.M.Hiegel, DOE  
David Jansen, Ecology  
Toby Michelena, Ecology  
Dave Nylander, Ecology  
Rick Oldham, WHC  
J.E. Rasmussen, DOE  
Doug Sherwood, EPA  
T. Veneziano, WHC



93129360002

## CORRESPONDENCE DISTRIBUTION COVERSHEET

Author	Addressee	Correspondence No.
Gary Anderson, Ecology	R. D. Izatt, RL	Incoming:9203012

subject: 241-A TANK FARM COOLING WATER SAMPLING AND ANALYSIS PLAN

### INTERNAL DISTRIBUTION

Approval	Date	Name	Location	w/att
		Correspondence Control	A3-01	
		President's Office	B3-01	
		M. C. Arntzen Jr	L4-56	
		G. T. Berlin	R1-51	
		W. R. Brown	B2-19	
		G. D. Carpenter	B2-16	
		C. K. DiSibio	B3-03	
		R. A. Dodd	R2-95	
		J. A. Eacker	R1-51	
		D. L. Flyckt	R3-45	
		C. J. Geier	B2-19	
		D. L. Halgren	R1-51	
		D. P. Hughes	R3-30	
		O. M. Jaka	R3-08	
		R. J. Landon	B2-19	
		R. E. Lerch, Assignee	B2-35	
		C. M. Loll	R1-51	
		M. D. Long	S5-03	
		P. J. Mackey	B3-15	
		H. E. McGuire, Level 1	B3-63	
		D. M. Nguyen	R1-48	
		S. M. Price	H4-57	
		R. W. Oldham	H4-57	
		R. T. Stordeur	R3-45	
		J. D. Williams	R1-48	
		EDMC	H4-22	
		EPS/File/LB	H4-57	

93129360003