

## Waste Site Reclassification Form

<b>Date Submitted:</b> 6/3/2004	<b>Operable Unit(s):</b> 200-UR-1	<b>Control Number:</b> 2004-087
<b>Originator:</b> C. R. Webb	<b>Waste Site ID:</b> UPR-200-W-87	
<b>Phone:</b> 373-5573	<b>Type of Reclassification Action:</b>	
	<b>Rejected:</b> <input type="radio"/> <b>No Action:</b> <input checked="" type="radio"/> <b>Interim Closed Out:</b> <input type="radio"/> <b>Closed Out:</b> <input type="radio"/>	


This form documents agreement among the parties listed below authorizing classification of the subject unit as rejected, closed-out, or no action and authorizing backfill of the site, if appropriate. Final removal from the NPL of no action or closed-out sites will occur at a future date.

**Description of current waste site condition:**

In 1982, water was being blown from the 219-S High Efficiency filter box up the exhaust stack. The smear of the liquid revealed no contamination. The decision was made to change the High Efficiency filter. The 219-S High Efficiency Particulate Air (HEPA) filter housing was opened for the filter change. As the coverplate bolts were removed, water began to run from the housing. The flow continued until it covered approximately 2.7 square meters (30 square feet). After the water soaked into the ground, 2,000 counts per minute beta gamma was found under the filter box, with 300 counts per minute on the remaining damp soil.

**Basis for reclassification:**

In 1982, the area was roped off and the contaminated soil was placed in drums before the end of the work day. In 1997, the W-87 project installed new transfer lines to a depth of 1.5 meters (5 feet). The area affected by this unplanned release was hand dug and backfilled. Asphalt now covers the affected area. It is recommended this site be reclassified to No Action.

Michael J. Royack		12/07/04
DOE Project Manager	Signature	Date
John B. Price		7/14/04
Ecology Project Manager	Signature	Date
EPA Project Manager	Signature	Date