

HNF-EP-0702  
Revision 1

# **Flammable Gas Project: Criteria for Flammable Gas Watch List Tanks**

Prepared for the U.S. Department of Energy  
Assistant Secretary for Environmental Management

Project Hanford Management Contractor for the  
U.S. Department of Energy under Contract DE-AC06-96RL13200

Approved for public release; distribution is unlimited

0047385

HNF-EP-0702

Revision 1

# Flammable Gas Project: Criteria for Flammable Gas Watch List Tanks

R. J. Cash  
DE&S Hanford, Inc.

Date Published  
January 1997

Prepared for the U.S. Department of Energy  
Assistant Secretary for Environmental Management

Project Hanford Management Contractor for the  
U.S. Department of Energy under Contract DE-AC06-96RL13200



Approved for public release; distribution is unlimited

**LEGAL DISCLAIMER**

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or any third party's use or the results of such use of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced from the best available copy. Available in paper copy and microfiche.

Available to the U.S. Department of Energy  
and its contractors from  
U.S. Department of Energy  
Office of Scientific and Technical Information (OSTI)  
P.O. Box 62  
Oak Ridge, TN 37831  
(615) 576-8401

Available to the public from the U.S. Department of Commerce  
National Technical Information Service (NTIS)  
5285 Port Royal Road  
Springfield, VA 22161  
(703) 487-4650

Printed in the United States of America

DISCLM-1.CHP (8-95)



# **Flammable Gas Project: Criteria for Flammable Gas Watch List Tanks**

**G. D. Johnson**  
Duke Engineering & Services Hanford, Inc.

Date Published  
January 1997

Prepared for the U.S. Department of Energy  
Assistant Secretary for Environmental Management

Project Hanford Management Contractor for the  
U.S. Department of Energy under Contract DE-AC06-96RL13200

Approved for public release; distribution is unlimited

**RELEASE AUTHORIZATION**

**Document Number:** HNF-EP-0702, Rev. 1


**Document Title:** Flammable Gas Project: Criteria for Flammable Gas Watch List Tanks

**Release Date:** 1/29/97

**This document was reviewed following the procedures described in WHC-CM-3-4 and is:**

**APPROVED FOR PUBLIC RELEASE**

**WHC Information Release Administration Specialist:**

  
Kara M. Broz

January 29, 1997

---

---

CONTENTS

1.0 INTRODUCTION ..... 1  
    1.1 PURPOSE ..... 1  
    1.2 BACKGROUND ..... 1  
  
2.0 CRITERIA FOR FLAMMABLE GAS WATCH LIST TANKS ..... 3  
  
3.0 REFERENCES ..... 4  
  
APPENDIX  
  
    A PUBLIC LAW 101-510 ..... A-1

This page intentionally left blank.

---

---

## 1.0 INTRODUCTION

### 1.1 PURPOSE

The Flammable Gas Watch List is the listing of tanks that are subject to the provisions of Public Law 101-510, Section 3137, "Safety Measures for Waste Tanks at Hanford Nuclear Reservation" (Appendix A). Tanks on the Flammable Gas Watch List are judged to have a serious potential for release of high-level waste due to the ignition of flammable gases released from the waste in the tank. The purpose of this document is to provide criteria for identifying and categorizing the Hanford Site high-level waste tanks to be included on the Flammable Gas Watch List. This document also provides criteria on which to base a recommendation to remove tanks from the Flammable Gas Watch List.

### 1.2 BACKGROUND

The potential for flammable and/or explosive conditions resulting from flammable gas (e.g., hydrogen) generation, retention, and release in high-level radioactive waste has long been recognized as a hazard. In 1990, the entrapment of large quantities of flammable gases within the waste of Hanford Site tank 241-SY-101 was recognized as a unique hazard requiring special attention and control. In April 1990, administrative controls were implemented for controlling activities within tank 241-SY-101 and other tanks that were identified as potentially having similar behavior (Bracken 1990). This was the first application of the term "Watch List" to Hanford tanks.

In May 1990, the U.S. Department of Energy, Richland Operations Office (RL), determined that the matter of hydrogen and nitrous oxide evolution within the material in certain waste tanks and subsequent hypothetical ignition was an unreviewed safety question (USQ) (Lawrence 1990). The USQ was applied to the tanks previously identified as tanks of concern in Bracken (1990).

In November 1990, Public Law 101-510 was passed. Section 3137 (Appendix A), also referred to as the Wyden Amendment, was part of this law. This section requires the Secretary of Energy to identify within 90 days which high-level nuclear waste tanks may have a "serious potential for release of high-level waste due to uncontrolled increases in temperature or pressure." Tanks were identified because they contained flammable gas, ferrocyanide, or organic chemicals, or because they had high radioactive decay heat. In January 1991, Westinghouse Hanford Company (WHC) formally submitted the Watch List of tanks subject to the law (Harmon 1991a). In February 1991, WHC submitted the selection methodology for flammable gas tanks (Harmon 1991b). This selection process was improved from the original 1990 process and two additional tanks were placed on the Watch List. Harmon (1991b) also included a proposed method for removing tanks from the Watch List. This Watch List identified 23 tanks subject to Public Law 101-510, Section 3137, because of

---

---

flammable gas hazards. In 1993, two additional tanks were added to the Flammable Gas Watch List (Fulton 1993, WHC 1993).

In August 1994, WHC issued *Criteria for Flammable Gas Watch List Tanks* (Hopkins 1994). Hopkins (1994) is superseded by this document, HNF-EP-0702, Revision 1. In addition, work controls to address flammable gas hazards have been implemented for all 177 tanks.

In October 1994, the U.S. Department of Energy, Headquarters, issued a memorandum providing guidance on modifications to the Hanford Site high-level waste tanks watch list (Lytle 1994). This memorandum stated that no laws or DOE Orders exist that establish the process or criteria for modifications to the Watch List. The memorandum further established that the Office of Environmental Management is the approval authority for modifications to the Watch List. Guidance was given that RL will discuss any proposed modifications to the Watch List with appropriate stakeholders.

## 2.0 CRITERIA FOR FLAMMABLE GAS WATCH LIST TANKS

The Flammable Gas Watch List is the listing of those single-shell or double-shell high-level nuclear waste tanks at the Hanford Site that may have a serious potential for release of high-level waste because of uncontrolled increases in temperature or pressure. The Flammable Gas Watch List is specific to those tanks in which the initiating event of the uncontrolled increase in temperature or pressure is a potential for flammable gas combustion.

The selection criterion for the Flammable Gas Watch List is as follows:

*Any tank that can have a flammable gas volume in the dome space that, when ignited, would result in pressure above a containment-related tank design limit will be categorized as a Flammable Gas Watch List tank.*

The criterion for removing tanks from the Flammable Gas Watch List is as follows:

*Any tank that no longer satisfies the selection criterion for the Flammable Gas Watch List will be removed from the Watch List.*

Analysis of tanks for gas release behavior must be based on a total reconciliation of all available data for the tank such that a consistent understanding of tank conditions is achieved. Once it is determined that a tank is a candidate for gas release behavior, the data must be assessed to determine that sufficient quality exists to perform quantitative calculations. Only when the data are deemed to be of sufficient quality will calculations of magnitude for potential gas release events be performed.

### 3.0 REFERENCES

- Bracken, G. J., 1990, *Flammable Gas/Slurry Growth Issues*, (letter to President, Westinghouse Hanford Company, April 2), U.S. Department of Energy, Richland Operations Office, Richland, Washington.
- Fulton, J. C., 1993, *Addition of Tank 241-AW-101 to the Flammable Gas Watch List*, (letter 9354700 to R. E. Gerton, U.S. Department of Energy, Richland, Operations Office, June 3), Westinghouse Hanford Company, Richland, Washington.
- Harmon, H. D., 1991a, *Safety Measures for Waste Tanks at Hanford Site, Richland, Washington*, (letter 9059124 to R. E. Gerton, U.S. Department of Energy, Richland Operations Office, January 8), Westinghouse Hanford Company, Richland, Washington.
- Harmon, H. D., 1991b, *Watch List for Tanks Which May Have Hydrogen Buildup*, (letter 9001478B R1 to R. E. Gerton, U.S. Department of Energy, Richland Operations Office, February 8), Westinghouse Hanford Company, Richland, Washington.
- Hopkins, J. D., 1994, *Criteria for Flammable Gas Watch List Tanks*, WHC-EP-702, Rev. 0, Westinghouse Hanford Company, Richland, Washington.
- Lawrence, M. J., 1990, *Unreviewed Safety Question - Waste Storage Tanks*, (memorandum to L. P. Duffy, U.S. Department of Energy, Headquarters, May 14), U.S. Department of Energy, Richland Operations Office, Richland, Washington.
- Lytle, J. E., 1994, *Action: Delegate Authority to the Office of Waste Management to Make Modifications to the Hanford High-Level Waste Tanks "Watch List"*, (memorandum to T. P. Grumbly, October 13), U.S. Department of Energy, Washington, D.C.
- Public Law 101-510, 1990, "Safety Measures for Waste Tanks at Hanford Nuclear Reservation," Section 3137 of *National Defense Authorization Act for Fiscal Year 1991*.
- WHC, 1993, *200 West Area Waste Tank 241-U-107 Added to the Flammable Gas Watch List*, Occurrence Report RL-WHC-TANKFARM-1993-0115, December 16, Westinghouse Hanford Company, Richland, Washington.

This page intentionally left blank.

**APPENDIX A**

**PUBLIC LAW 101-510 (H.R. 4739), NOVEMBER 1990,  
NATIONAL DEFENSE AUTHORIZATION ACT FOR  
FISCAL YEAR 1991**

**Section 3137: Safety Measures for  
Waste Tanks at Hanford  
Nuclear Reservation**

APPENDIX A

**PUBLIC LAW 101-510 (H.R. 4739), NOVEMBER 1990,  
NATIONAL DEFENSE AUTHORIZATION ACT FOR  
FISCAL YEAR 1991**

**Section 3137: Safety Measures for  
Waste Tanks at Hanford  
Nuclear Reservation**

**(a) Identification and Monitoring of Tanks.** Within 90 days after the date of the enactment of this Act, the Secretary of Energy shall identify which single-shelled or double-shelled high-level nuclear waste tanks at the Hanford Nuclear Reservation, Richland, Washington, may have a serious potential for release of high-level waste due to uncontrolled increases in temperature or pressure. After completing such identification, the Secretary shall determine whether continuous monitoring is being carried out to detect a release or excessive temperature or pressure at each tank so identified. If such monitoring is not being carried out, as soon as practicable the Secretary shall install such monitoring, but only if a type of monitoring that does not itself increase the danger of a release can be installed.

**(b) Action Plans.** Within 120 days after the date of the enactment of this Act, the Secretary of Energy shall develop action plans to respond to excessive temperature or pressure or a release from any tank identified under subsection (a).

**(c) Prohibition.** Beginning 120 days after the date of the enactment of this Act, no additional high-level nuclear waste (except for small amounts removed and returned to a tank for analysis) may be added to a tank identified under subsection (a) unless the Secretary determines that no safer alternative than adding such waste to the tank currently exists or that the tank does not pose a serious potential for release of high-level nuclear waste.

**(d) Report.** Within six months after the date of the enactment of this Act, the Secretary shall submit to Congress a report on actions taken to promote tank safety, including actions taken pursuant to this section, and the Secretary's timetable for resolving outstanding issues on how to handle the waste in such tanks.

This page intentionally left blank.

This page intentionally left blank.

---

---

**DISTRIBUTION**

Number of copies

OFFSITE

3	<u>U.S. Department of Energy</u> EM-38, Trevion II 12800 Middlebrook Road Germantown, MD 20874  Harry Calley Dave Pepson Ken Lang
1	<u>Argonne National Laboratory</u> 9700 S. Cass Avenue Argonne, IL 60439  Danny Meisel
1	Harry Babad 2540 Cordoba Court Richland, WA 99351
1	David O. Campbell 102 Windham Road Oak Ridge, TN 37830
1	Billy C. Hudson 202 Northridge Court P.O. Box 271 Lindsborg, KA 67456
1	Thomas S. Kress 102-B Newridge Road Oak Ridge, TN 37830
1	Thomas E. Larson 2711 Walnut Street Los Alamos, NM 87544

**DISTRIBUTION (Continued)**

- 2            Fauske and Associates, Inc.  
16W070 W. 83rd St.  
Burr Ridge, IL 60521
- Marty G. Plys  
Hans K. Fauske
- 1            G & P Consulting, Inc.  
3640 Ballard Road  
Dallas, OR 97338
- Arlin K. Postma
- 3            Los Alamos National Laboratory  
P.O. Box 1663  
Los Alamos, NM 87545
- W. L. Kubic            K557  
K. Pasamehmetoglu   K555  
C. Unal                K575
- 1            Nuclear Consulting Services, Inc.  
P.O. Box 29151  
Columbus, OH 43229-0151
- J. Louis Kovach
- 1            Oak Ridge National Laboratory  
P.O. Box 2008  
Oak Ridge, TN 37831-6495
- Charles W. Forsberg, MS-6495
- 2            Sandia National Laboratories  
P.O. Box 5800  
Albuquerque, NM 87185
- Dana A. Powers, MS-0744  
Scott E. Slezak, MS-0741

**DISTRIBUTION (Continued)**

1                    State of Washington - Department of Ecology

Alex B. Stone  
 1315 W. 4th Avenue  
 Kennewick, WA 99336

1                    Westinghouse Savannah River Company

Savannah River Site 241-121H  
 Aiken, SC 29802

Susan J. Eberlein

ONSITE

12                    U.S. Department of Energy,  
Richland Operations Office

M. H. Campbell	S7-73
K. Chen	S7-54
J. M. Gray	S7-54
C. A. Groendyke	S7-54
M. A. Hunemuller	S7-50
D. H. Irby	S7-54
J. K. McClusky	S7-54
G. W. Rosenwald	S7-54
C. L. Sohn	S7-51
Public Reading Room	H2-53
RL Docket File (2)	B1-17

51                    Hanford Contractors

S. A. Barker	R2-11
W. B. Barton	R2-11
R. E. Bauer	S7-14
D. R. Bratzel	S7-14
R. J. Cash (3)	S7-14
A. F. Choho	H6-36
R. A. Dodd	S5-07
G. L. Dunford	A2-34
W. M. Funderburke	R2-38
T. C. Geer	R2-38
J. M. Grigsby	R1-49

**DISTRIBUTION (Continued)**

R. C. Hill	R1-51
K. M. Hodgson	H0-34
G. D. Johnson (10)	S7-14
N. W. Kirch	R2-11
J. G. Kristofzski	R2-12
C. E. Leach	R1-49
J. W. Lentsch	S2-48
J. E. Meacham	S7-14
W. H. Meader	S8-05
D. M. Ogden	H0-34
M. A. Payne	S7-84
L. D. Pennington	S7-21
D. A. Reynolds	R2-11
S. H. Rifaey	R1-56
W. E. Ross	S5-07
O. M. Serrano	R2-12
J. P. Slougher	R2-54
J. S. Schofield	S7-12
E. R. Siciliano	H0-31
L. M. Stock	S7-14
A. M. Umek	S7-81
R. J. Van Vleet	A3-34
D. J. Washenfelder	S7-40
J. R. White	S7-15
J. H. Wicks	R2-50
N. E. Wilkins	R2-11
Central Files	A3-88
EDMC	H6-08
DPC	A3-94

ONSITE

16

Pacific Northwest National Laboratory

Z. I. Antoniak	K7-15
J. M. Bates	K7-15
J. W. Brothers	K5-22
S. A. Bryan	P7-25
D. M. Camaioni	K2-44
J. A. Campbell	P8-08
P. A. Gauglitz	P7-41
R. T. Hallen	P8-38

**DISTRIBUTION (Continued)**

J. L. Huckaby	K6-80
B. J. Palmer	K7-15
F. E. Panisko	K8-34
L. R. Pederson	K2-44
A. Shekarriz	K7-15
C. W. Stewart	K7-15
P. D. Whitney	K5-12
Hanford Technical Library	P8-55

This page intentionally left blank.