


FOR COMPLETE INSTRUMENT TAG NUMBERS, REFERENCE SPECIFICATION: B-595-C-A160 SECTION 17704, ATTACHMENT B & C.


14. ALL FIREWATER PIPING SYSTEMS (PIPE LINE SERVICE FWX) ARE DESIGNED FOR SAFETY CLASS 1 DESIGN BASIS EARTHQUAKE (DBE) EXCEPT AS NOTED. STANDARD DETAILS USED WITH THE FIREWATER PIPING SYSTEMS ARE DESIGNED FOR SAFETY CLASS 1 DESIGN BASIS EARTHQUAKE.
15. WHERE CONSTRUCTION CONFLICTS MAY OCCUR WITH EXISTING FIELD OBJECTS, THE SELLER SHALL NOTIFY THE BUYER OF THESE POTENTIAL CONFLICTS PRIOR TO PERFORMING ANY RELATED WORK.

0018072

START

DEC 19 1991



REV NO.	DATE	REVISION DESCRIPTION	APPROVAL INITIALS				
0	12/19/91	APPROVED FOR CONSTRUCTION	RK	RAC	JCD / GKB / GK		
CADFILE	B124020A		CADCODE	2B:IBM:ACD2:10.C2:SS			
ENGINEERING RELEASE		U.S. DEPARTMENT OF ENERGY Richland Operations Office DE - AC06-86RL10838					
REV.	DATE						
SIGNATURE		DATE	 FLUOR DANIEL, INC. ADVANCED TECHNOLOGY DIVISION GENERAL NOTES, KEY PLAN, LEGEND, SYMBOLOGY AND ABBREVIATIONS				
PROJ. DIR.		12/19/91					
Q.A. ENG.		12/19/91					
INDEPENDENT SAFETY		12/19/91					
PROJECT PKG ENGINEER		12/17/91					
ENGINEERING MGR.		12-17-91					
SUPERVISOR		12/16/91					
DESIGN ENGINEER		12/16/91					
CHECKED		12/12/91					
DRAWN		11/16/90					
CLASSIFICATION		BY	DRAWING NUMBER		SHEET	OF	REV.
NONE		NOT REQ'D	H-2-124020		1	1	0

B

A

2

1

DISTRIBUTION CODE : 501 & 503

M1

ACAD

12/12/91
D.P.L.