

START

RECEIVED

JUL 15 1993

T.B. VENEZIANO



STATE OF WASHINGTON

DEPARTMENT OF ECOLOGY

7601 W. Clearwater, Suite 102 • Kennewick, Washington 99336 • (509) 546-2990

July 12, 1993

Mr. James Bauer
 U.S. Department of Energy-RL
 P.O. Box 550
 Richland, WA 99352

Dear Mr. Bauer:

Re: C-018H Project

This letter is to inform you that much of the concrete work done thus far on the referenced project is substandard. The quality of the workmanship exhibited by the contractors is inadequate for a facility handling hazardous wastes.

The examples of poor workmanship that I have observed include ridges, swirls, and depressions in finished slabs. Additionally, bulges and low spots are evident in foundations and walls.

Because of these problems, it is necessary for action to be taken to demonstrate improved workmanship before the work involves more sensitive areas of the project. Please inform me of the action you intend to take to rectify this situation.

If you have any questions regarding this matter, please call me at (509) 736-3017.

Sincerely,

A handwritten signature in cursive script that reads "Jerry Hensley".

Jerry Hensley
 Nuclear & Mixed Waste Management Program

JH:mf

cc: Dana Bryson, DOE
 Tony Veneziano, DOE
 Armin Vogt, WHC
 Dan Duncan, EPA
 Administrative File



Reissued 07/19/93

CORRESPONDENCE DISTRIBUTION COVERSHEET

Author: J. Hensley, Ecology Addressee: J. D. Bauer, RL Correspondence No.: Incoming Ltr. #9304662B

Subject: C-018H PROJECT

INTERNAL DISTRIBUTION

Approval	Date	Name	Location	w/att
		Correspondence Control	A3-01	
		President's Office	B3-01	
		B. A. Austin	B2-35	
		G. W. Jackson	H6-20	
		D. E. Kelley	R3-45	
		J. R. Kelly*	R3-28	
		M. K. Korenko, Level 1	B3-08	
		R. E. Lerch	B3-63	
		D. W. Lindsey	R3-45	
		H. E. McGuire	B3-63	
		L. L. Powers	L4-96	
		T. C. Varljen, Assignee	H5-27	
		T. B. Veneziano	L4-96	
		A. K. Vogt	L4-94	
		B. F. Weaver	N1-73	
		EDMC	H6-08	

*Responsible Individual.

Reissued to show appropriate Assignee and additional distribution.

Reissued 07/19/93

DMHV

9312971.2165

