

RECEIVED  
NOV 14 2007

0074340

EDMC

Waste Site Reclassification Form

<b>Date Submitted:</b> 8/3/1998	<b>Operable Unit(s):</b> 300-FF-2	<b>Control Number:</b> 98-043
<b>Originator:</b> C. E. Corriveau, Jr., MSIN H0-17	<b>Waste Site ID:</b> 300-85	
<b>Phone:</b> 372-9565	<b>Type of Reclassification Action:</b> Rejected <input checked="" type="radio"/> Closed-Out <input type="radio"/> No Action <input type="radio"/>	

This form documents agreement among the parties listed below authorizing classification of the subject unit as rejected, closed-out, or no action and authorizing backfill of the site, if appropriate. Final removal from the NPL of no action or closed-out sites will occur at a future date.


Description of current waste site condition:

The site is a 150 centimeter (60 inch) diameter vertical steel caisson with a sloping steel lid. An access door is located on the lid. The interior of the caisson contains several pipes and valves. The site appears to be a valve pit. The site is posted as a confined space. The site is listed in the "Inventory of Miscellaneous Streams", Revision 3, as miscellaneous stream #453.

Basis for reclassification:

Steam is produced from sanitary water that has been sent through a water softener system to remove minerals (calcium and magnesium). The treated water is introduced into boilers to produce steam. This steam is superheated before distribution to facilities for heating and process use. Disposal sites receive steam condensate from the steam distribution lines. When used for heating purposes, this is a seasonal discharge. Non-regulated chemicals are added to dechlorinate the water, prevent scale, and control corrosion.

The site is active and receives less than 0.038 liters (0.01 gallons) per minute steam overflow from the package boilers. Disposal structures meeting the definition of "underground injection control", as stated in WAC 173-218, are registered (listed) as underground injection wells. This site is exempt from permitting under WAC 173-216 because Ecology considers the WAC 173-218 registration to be sufficient for sites that received steam condensate only.

_____		
DOE Project Manager	Signature	Date
_____	_____	_____
Ecology Project Manager	Signature	Date
_____		
EPA Project Manager	Signature	Date