

9713540-1144

# HANFORD ADVISORY BOARD

036391

Site Specific Advisory Board, Chartered under the Federal Advisory Committee Act

0045203

September 6, 1996

**Advising:**

US Dept of Energy  
US Environmental  
Protection Agency  
Washington Dept of  
Ecology

John Wagoner, Manager  
Department of Energy, Richland Operations  
PO Box 550 (A7-50)  
Richland, WA 99352

**CHAIR**

Merilyn Reeves

Chuck Clarke, Regional Administrator

**BOARD MEMBERS:**

U.S. Environmental Protection Agency, Region 10  
1200 Sixth Avenue  
Seattle, WA 98101

**Local Business**

Harold Heacock  
Frank Ochoa

Mary Riveland, Director  
Washington Department of Ecology  
PO Box 47600  
Olympia, WA 98504-7600

**Labor/Work Force**

Richard Berglund  
Thomas Carpenter  
Mark Hermanson  
Gerald Sorensen  
Jim Watts

**Local Environment**

Rick Leumont

**Local Government**

Pam Brown  
Ben Floyd  
Charles Kilbury  
George Kyriazis  
Robert Larson  
Jerry Peltier  
Bill Riley

RE: Utilizing Effluent Treatment Facility (ETF) to treat pumped water from 200 UP-1  
(HAB Advice #52)

Dear Messrs. Clarke and Wagoner, and Ms. Riveland:

**Background**

The Hanford Advisory Board has previously advised the Tri-Party Agencies on Guidelines for Interim Use of Pump and Treat, Consensus Advice #3, July 8, 1994, and recommended continued funding for 200 UP-1 Groundwater Treatability Testing in Consensus Advice #17, Part IV.A. as revised, May 4, 1995. DOE is now considering treating pumped water from the 200 UP-1 Operable Unit in the Effluent Treatment Facility (ETF). Currently water at 200 UP-1 is treated onsite and re-injected. Use of ETF is cost effective. Additionally, the ETF removes contaminants that UP-1 equipment is unable to treat, such as nitrates and other contaminants that would otherwise be returned to the groundwater.

The ER Committee recommends the use of the ETF so long as the Department of Ecology, EPA and DOE can work out regulatory requirements regarding the transfer pipes. The Committee brought this recommendation to the HAB at its May meeting, but due to time constraints, it was postponed. This proposal is now out for public comment and time is of the essence.

HAB Advice #52

Subject: Utilizing Effluent Treatment Facility (ETF) to treat pumped water from 200 UP-1  
Adopted: September 5-6, 1996

Page 1

Contact: Confluence Northwest Hallmark Associates, Facilitation Team

1220 SW Morrison, Tenth Floor, Portland OR 97205


Phone (503) 243-2493 Fax (503) 243-3683

Advice

The Hanford Advisory Board recommends the use of the 200 Area Effluent Treatment Facility (ETF) to treat pumped water from the 200 Area UP-1 Operable Unit so long as the Washington Department of Ecology, US EPA and USDOE can work out the regulatory requirements involved. This proposal is cost effective and would remove additional contaminants such as nitrates and other contaminants that the UP-1 equipment is unable to treat.

The Board looks forward to your written response, as called for in our charter.

Very truly yours,



Marilyn B. Reeves, Chair  
Hanford Advisory Board

cc: Cindy Kelly, Designated Federal Official  
Linda Lingle, Site Representative  
The Oregon and Washington Congressional Delegations