

START



STATE OF WASHINGTON
DEPARTMENT OF HEALTH

1500 West 4th Avenue, Suite 305 • Spokane, Washington 99204
FAX (509) 456-2997

August 10, 1994

ATTN: Mr. J.E. Rasmussen
U.S. Department of Energy
Environmental Assurance, Permits & Policy
Richland Field Office
M.S. A5-15
Richland, WA 99352

RE: Hanford Project C-018H (KEH 5422), 7,000 Gallon
Fiberglass Septic Tank

Dear Mr. Rasmussen:

The plans and specifications for the above tank received in this office August 5, 1994 have been reviewed and, in accordance with the provisions of WAC 246-272 are hereby APPROVED.

PROVIDED: Top of the sanitary tees shall be extended to within 2 inches of the top underside of the tank to allow for adequate scum storage.

Sincerely,

Lisa Brown

Lisa Brown, P.E.
Environmental Engineer
Large On-Site Systems
(509) 456-2754

cc: DOE Nuclear and Mixed Waste Management, Jerry Hensley
~~Westinghouse Hanford, J. Stan Hill~~
Kaiser Engineers, Charles Mortimer
Benton-Franklin County Health District
State Health
Fiberglass Structures, Inc., Bob Nation



CORRESPONDENCE DISTRIBUTION COVERSHEET

Author

L. Brown, DOH
(J. S. Hill, WHC)

Addressee

J. E. Rasmussen, RL

Correspondence No.

Incoming: 9403845
Xref: 9403833 37904
Xref: 9454772D 37903

Subject: HANFORD PROJECT C-018H (KEH 5422), 7,000 GALLON FIBERGLASS SEPTIC TANK

INTERNAL DISTRIBUTION

Approval	Date	Name	Location	w/att
		Correspondence Control	A3-01	
		L. P. Diediker	T1-30	
		W. T. Dixon, Assignee	H6-21	
		K. A. Giese	H6-25	
		J. S. Hill	H6-25	
		J. R. Kelly	R3-28	
		J. J. Luke	H6-25	
		P. J. Mackey	B3-15	
		H. E. McGuire, Sr. Staff	B3-63	
		M. A. Nevills	S4-61	
		J. J. Noble	L4-76	
		J. A. Thornock	S4-61	
		A. K. Vogt	L4-94	
		B. D. Williamson	B3-15	
		EPIC	H6-08	
		Project Files	R1-28	
		JSH/File/LB	H6-25	