

START

7415299.1459

0039213

Meeting Minutes Transmittal

224-T TRANSURANIC WASTE STORAGE AND ASSAY FACILITY
Unit Managers Meeting
Federal Building, Room 784B
Richland, Washington

July 7, 1994
10:00 a.m. - 12:00 p.m.

The undersigned indicate by their signatures that these meeting minutes reflect the actual occurrences of the above dated Unit Managers Meeting.

RC Bowman for

Clifford E. Clark, Unit Manager, RL
(Represented by Roger C. Bowman, WHC)

Date: 11/10/94

Not Present

Daniel L. Duncan, RCRA Program Manager, EPA Region 10

Date: _____

Alisa D. Huckaby

Alisa D. Huckaby, Unit Manager, Washington State Department of Ecology

Date: 11/10/94

224-T Transuranic Waste Storage and Assay Facility, WHC Concurrence

Brett M. Barnes for

Richard D. Pierce, Contractor Representative, WHC
(Represented by Brett M. Barnes, WHC)

Date: 11/10/94

Purpose: Discuss Permitting Process

Meeting Minutes are attached. The minutes are comprised of the following:

- Attachment 1 - Agenda
- Attachment 2 - Summary of Discussion and Commitments/Agreements
- Attachment 3 - Attendance List
- Attachment 4 - Action Items



Attachment 1

**224-T TRANSURANIC WASTE STORAGE AND ASSAY FACILITY
Unit Managers Meeting
Federal Building, Room 784B
Richland, Washington**

**July 7, 1994
10:00 a.m. - 12:00 p.m.**

Agenda

1. MEETING MINUTES
2. STATUS OF RESPONSE TO NOTICE OF DEFICIENCY RESPONSE TABLE
3. ACTION ITEMS
4. GENERAL DISCUSSION
5. SET NEXT MEETING DATE

Attachment 2**224-T TRANSURANIC WASTE STORAGE AND ASSAY FACILITY
Unit Managers Meeting
Federal Building, Room 784B
Richland, Washington****July 7, 1994
10:00 a.m. - 12:00 p.m.****Summary of Discussion and Commitments/Agreements****1. MEETING MINUTES**

The March 15, 1994 Unit Manager Meeting minutes were approved. There were no Unit Manager Meetings held in April or May 1994.

2. STATUS OF RESPONSE TO NOTICE OF DEFICIENCY RESPONSE TABLE

Ms. A. Huckaby (Ecology) stated that due to Ecology's focus on the Hanford Facility permit, she had not initiated a review of the NOD response table.

3. ACTION ITEMS

Action item 3-15-94:1, WHC will provide Ecology (Ms. Huckaby) a copy of the engineering study and the analysis that was done to identify compliance issues at TRUSAF, and a copy of the ADSs related to TRUSAF's proposed budget.

Mr. D. Saueressig (WHC) stated that the engineering study is in the process of being finalized, and a copy will be provided to Ms. Huckaby as soon as it is cleared. Mr. Saueressig provided copies of the ADSs for Ms. Huckaby. This action item was left open.

Action item 6-1-94:1, WHC will provide Ecology (Ms. Huckaby) information regarding evaluation of the integrity of the roof.

Mr. Saueressig stated that the evaluation report has been completed, and it is being finalized. A copy will be provided to Ms. Huckaby by the next Unit Managers Meeting. This action item was left open.

Mr. C. Cejka (WHC) noted that the information resulting from evaluation of the roof indicates the roof is structurally sound. A load test using a 500-pound robot was performed, and no deflection on the roof was found. Ms. Huckaby inquired about corroded rebar in the building, and asked if evaluation of the rebar was included in the report. Mr. Cejka pointed out that the rebar in the closed area cannot be evaluated due to ALARA concerns, and the decision was made to perform the load test. Mr. Cejka added that if the rebar is corroding there would be rust coloration on the ceiling, and that he saw no evidence of

corrosion. Mr. R. Bowman (WHC) pointed out that the load testing checks the integrity of the rebar.

Ms. Huckaby stated that she had noted discoloration on the ceiling, and asked Mr. Cejka if he had visually surveyed the ceiling. Mr. Cejka responded that he had, and that he did not believe the ceiling stains were a result of corroding rebar.

Ms. Huckaby inquired about resolution of the leaks in the roof. Mr. Cejka stated that water could be coming from different areas in the building other than the roof, and that the plan is to wait until the water appears and then analyze the situation.

Ms. Huckaby requested WHC take an action to make an effort to determine the location of the water when it appears in the facility, and that Ms. Huckaby be contacted so she can conduct a visual inspection.

4. GENERAL DISCUSSION

Ms. Huckaby stated that the equipment at TRUSAF may need to be upgraded to improve analytical capabilities, and inquired about comparing the assay and x-ray technologies used at TRUSAF and the Central Waste Complex. Ms. Huckaby also requested an example of the documentation obtained at the Central Waste Complex after assay and x-ray is performed. Mr. B. Barnes (WHC) agreed to provide Ms. Huckaby information showing the capabilities of the assay and x-ray equipment at TRUSAF and Central Waste Complex and the documentation of the results.

5. SET NEXT MEETING DATE

The next Unit Managers Meeting was scheduled for August 11, 1994.

Attachment 4

224-T TRANSURANIC WASTE STORAGE AND ASSAY FACILITY
Unit Managers Meeting
Federal Building, Room 784B
Richland, Washington

July 7, 1994
10:00 a.m. - 12:00 p.m.

Action Items

<u>Action Item #</u>	<u>Description</u>
3-15-94:1	WHC will provide Ecology (Ms. Huckaby) a copy of the engineering study and the analysis that was done to identify compliance issues at TRUSAF, and a copy of the ADSs related to TRUSAF's proposed budget. ACTION: D. Saueressig (WHC) OPEN
6-1-94:1	WHC will provide Ecology (Ms. Huckaby) information regarding evaluation of the integrity of the roof. ACTION: D. Saueressig (WHC) OPEN
7-7-94:1	WHC will analyze the situation when water appears in the facility to determine the source of the water, and Ms. Huckaby will be contacted so she can conduct a visual inspection. ACTION: C. Cejka (WHC) OPEN

Distribution:

L. D. Arnold	WHC	B2-35
B. M. Barnes	WHC	T3-04
R. C. Bowman	WHC	H6-24
B. J. Broomfield	WHC	T3-04
R. M. Carosino	RL	A4-52
C. C. Cejka	WHC	T4-03
C. E. Clark	RL	A5-15
D. L. Duncan	EPA	HW-106
R. M. Gordon	RL	S7-55
R. F. Guercia	RL	S7-55
A. D. Huckaby	Ecology	N1-08
M. N. Jaraysi	Ecology	N1-08
D. W. Lloyd	GSSC	B1-42
P. J. Mackey	WHC	B3-15
R. D. Pierce	WHC	T3-04
D. B. Powell	WHC	T4-03
J. W. Pratt	WHC	T4-04
S. M. Price	WHC	H6-23
D. G. Saueressig	WHC	H6-24
H. T. Tilden II	PNL	P7-68
M. L. Walsh	WHC	H6-20
RCRA Files/GHL	WHC	H6-23

ADMINISTRATIVE RECORD: 224-T Transuranic Waste Storage and Assay Facility,
S-2-2 [Care of EPIC, WHC (H6-08)]

Washington State Department of Ecology Nuclear and Mixed Waste Library,
P.O. Box 47600, Olympia, Washington 98504-7600

Environmental Protection Agency Region 10, Seattle, Washington 98101, Mail
Stop HW-106

Please send comments on distribution list to K. E. Knox, WHC H6-24,
(509) 372-3596