



0022045

STATE OF WASHINGTON  
DEPARTMENT OF ECOLOGY

Mail Stop PV-11 • Olympia, Washington 98504-8711 • (206) 459-6000

May 11, 1992

Mr. Ron D. Izatt  
United States Department of Energy  
P.O. Box 550  
Richland, WA 99352

Re: 284-E Powerplant Sampling and Analysis Plan

Dear Mr. Izatt:

I have reviewed the Sampling and Analysis Plan of the 284-E Area Powerplant, WHC-SD-WM-PLN-034, Revision 1. I have the following comments:

Section 1.1, SAMPLING OBJECTIVES, next to last sentence - Add "legally defensible" to the provisions of this program.

All sections should refer to SW-846 as "latest edition" or "as amended". SW-846 has been amended since 1986.

Page 1.7 - Include the composition of all proprietary additives used in steam generation.

Page 2.1 - We will have to insist that a sample tap be installed at sample location 6.

Page 2.11 - Be certain that Table 2.2 conforms to 40 CFR 136.3.

This is a very thorough sampling and analysis plan.

If you have any questions about this letter, please call me at (206) 438-7558.

Sincerely,

  
Gary Anderson, P.E.  
Environmental Engineer 3  
Nuclear and Mixed Waste Management

GA:jw

cc: Dan Duncan, EPA  
J.M.Hennig, DOE  
R.M.Hiegel, DOE  
Rick Oldham, WHC  
J.E. Rasmussen, DOE  
Doug Sherwood, EPA  
T. Veneziano, WHC  
Dave Nylander, Ecology



