



STATE OF WASHINGTON
DEPARTMENT OF HEALTH

West 924 Sinto Avenue • Spokane, Washington 99201-2595 • FAX (509) 456-2997

ATTN: S.D. Stites
U.S. Department of Energy
Environmental Restoration Division
Richland Field Office M.S. A5-19
Richland WA 99352

March 23, 1992

RE: Project L-092 Domestic Wastewater Septic System Emergency Replacement, Engineering Report, Plans and Specifications, Design Flow 14,297 Gallons per Day

Dear Mr. Stites:

The revised plans and specifications and subject report for the above project received in this office February 20, 1992 together with additional information received March 11, 1992 have been reviewed and, in accordance with the provisions of WAC 246-272 are hereby **APPROVED**.


PROVIDED: That an Operation and Maintenance Manual shall be prepared by a licensed engineer and submitted to the Department of Health within 60 days following construction completion. This approval acknowledges and concurs to waive the requirement for the use of bed systems in type 3 and 4 soils. Based on a site review made March 10, 1992, it is not anticipated that any of the proposed systems will have the bottom of the excavation in type 3 or 4 soils.

As required in WAC 246-272-080 - Within sixty days following the completion of and prior to the use of the above project or portions thereof, the attached Certification must be completed by a professional engineer and returned to this department.

WAC 246-272-080 provides that if the certification of completion has not been submitted within two years of the date of this letter, this approval will become null and void unless you take action at that time to arrange for an extension of the approval period in the manner prescribed.

Regulations establishing a schedule of fees for review of planning, engineering and construction documents were adopted July 1, 1987 (WAC 246-272-990). An itemized bill will be sent at a later date.

Sincerely,


George B. Schlender, Program Manager
Larger On-site Systems
(509) 456-2490

GBS:aa

Enclosure

cc: Benton-Franklin County Health District
State Health
DOE, Hanford Project, Roger Stanley
Kaiser Engineers, Charles Mortimer
Westinghouse Hanford, Kathy Jensen



CORRESPONDENCE DISTRIBUTION COVERSHEET

Author	Addressee	Correspondence No.
G. B. Schlender, DOH	S. D. Stites, RL	Incoming:9202334 XREF:9251048D XREF:9202326

Subject: PROJECT L-092, DOMESTIC WASTEWATER SEPTIC SYSTEM EMERGENCY
REPLACEMENT, ENGINEERING REPORT, PLANS AND SPECIFICATIONS, DESIGN FLOW
14,297 GALLONS PER DAY

INTERNAL DISTRIBUTION

Approval	Date	Name	Location	w/att
		Correspondence Control	A3-01	
		S. D. Bolling	H4-57	
		G. D. Carpenter	B2-16	
		C. K. DiSibio	B3-03	
		C. J. Geier	B2-19	
		B. C. Harmon	N1-30	
		R. L. Ingram	S1-06	
		K. S. Jensen	H4-57	
		D. M. Korte	S4-16	
		R. E. Lerch, Assignee	B2-35	
		P. J. Mackey	B3-15	
		D. E. Maki	B4-40	
		H. E. McGuire, Level 1	B3-63	
		R. W. Oldham	H4-57	
		S. M. Price	H4-57	
		D. J. Tollefson	N1-30	
		EDMC	H4-22	
		Project Files	R1-28	
		FILE/LB	H4-57	