

START



Department of Energy

Richland Operations Office
P.O. Box 550
Richland, Washington 99352

OCT 24 1994

95-PCA-034

Mr. George B. Schlender, Program Manager
Larger On-Site and Municipal
Wastewater Reuse Systems
State of Washington
Department of Health
1500 W. 4th Suite 305
Spokane, Washington 99204

Dear Mr. Schlender:

QUARTERLY INSPECTION RECORD FORM FOR THE 200 AREA EFFLUENT TREATMENT FACILITY
(PROJECT C-018H) TEMPORARY SANITARY WASTEWATER HOLDING SYSTEM

This letter transmits the Inspection Record Form (Form) for the 200 Area Effluent Treatment Facility (Project C-018H) Temporary Sanitary Wastewater Holding System. Submittal of the Form fulfills Washington Administration Code 246-272-080 septic holding tank reporting requirements.

The completed Form is for the third quarter of the calendar year, which covers the time period of June 24, 1994, through September 15, 1994. The information recorded on the Form indicates that the subject wastewater holding system components functioned properly; and the holding system operated within design limitations, with the exception of an elevated wastewater volume alarm signal on September 15, 1994. Corrective actions taken as a result of the alarm ensured that no wastewater discharges to the environment occurred.

Should you have any questions, please contact me or H. M. Rodriguez of my staff on (509) 376-5441.

Sincerely,

James D. Bauer

James D. Bauer, Program Manager
Office of Environmental Assurance,
Permits, and Policy

EAP:HMR



Enclosure

cc w/encl:
Administrative Records, H6-08
J. Hensley, Ecology
R. Stanley, Ecology
D. Lloyd, MACTEC

cc w/o encl:
L. Diediker, WHC
W. Dixon, WHC
B. Erlandson, WHC
J. Kelly, WHC
J. Luke, WHC

9413294.3057

EFFLUENT TREATMENT FACILITY QUARTERLY INSPECTION RECORD FORM

Project C-018H

COMPONENT/TASK	FREQUENCY	DATE	DATE	DATE
ALARM PANEL				
CHECK FLOAT SWITCH OPERATION	MONTHLY	7/1/94	8/19/94	9/13/94
MANUALLY OPERATE CONTROLS	MONTHLY	7/1/94	8/19/94	9/13/94
HOLDING TANK				
MANHOLE SEAL	MONTHLY	7/1/94	8/19/94	9/13/94
CHECK INLETS and OUTLETS	MONTHLY	7/1/94	8/19/94	9/13/94

VOLUME PUMPED (estimate)

DATE	ESTIMATED GALLONS PUMPED
24-JUNE-1994	1,500 GALLONS
28-JUNE-1994	500 GALLONS
1-JULY-1994	1,500 GALLONS
6-JULY-1994	1,000 GALLONS
8-JULY-1994	1,400 GALLONS
12-JULY-1994	800 GALLONS
15-JULY-1994	500 GALLONS
19-JULY-1994	500 GALLONS
22-JULY-1994	1,000 GALLONS
26-JULY-1994	250 GALLONS
29-JULY-1994	1,000 GALLONS
2-AUGUST-1994	600 GALLONS
4-AUGUST-1994	500 GALLONS
9-AUGUST-1994	500 GALLONS
17-AUGUST-1994	2,000 GALLONS
19-AUGUST-1994	250 GALLONS
23-AUGUST-1994	1,200 GALLONS
26-AUGUST-1994	1,200 GALLONS
30-AUGUST-1994	800 GALLONS

8503-1628-116

EFFLUENT TREATMENT FACILITY
QUARTERLY INSPECTION RECORD FORM

Project C-018H

DATE	ESTIMATED GALLONS PUMPED
2-SEPTEMBER-1994	1,000 GALLONS
7-SEPTEMBER-1994	2,000 GALLONS
9-SEPTEMBER-1994	500 GALLONS
13-SEPTEMBER-1994	1,800 GALLONS
15-SEPTEMBER-1994	1,000 GALLONS

"Significant Events"

Comments Section:

9/15/94 Received a call from the Building Administrator requesting pumping services. System was alarming due to a constantly running toilet. A total of 1,000 gallons was removed, and the alarm was restored back to normal operating condition at approximately 1500hrs.

9/13/94 3:05P