PCN-LERF/ETF-2025-02

Hanford Facility RCRA Permit Modification Notification Forms

Part III, Operating Unit ~~X~~ 3

LERF and 200 Area ETF

Index

Page 2 of 2: Addendum B, Waste Analysis Plan

Submitted by H2C Co-Operator:

Kembel, Monica R Digitally signed by Kembel, Monica R Date: 2025.11.04 13:33:05 -08'00'

Monica R. Kembel Date

Reviewed by DOE-ECD:

DUANE CARTER Digitally signed by DUANE CARTER Date: 2025.11.05 05:19:12 -08'00'

Duane B. Carter Date

PCN-LERF/ETF-2025-02

Hanford Facility RCRA Permit Modification Form

Unit:	Permit Part
Liquid Effluent Retention Facility & 200 Area Effluent Treatment Facility	***Part III, Operating Unit Group 3***

Description of Modification:

Addendum B, Waste Analysis Plan:

- Section B.3.2, Listed Waste Code Decontamination Process: Clarified water type to include "potable, or raw" water, along with verification water, based on location of decontamination (seven instances of update in section).
- Section B.3.2.1, Decontaminate Liquid Effluent Retention Facility Basins of Listed Waste Codes: Added paragraph to clarify current cover repair process. "Decontamination of listed waste codes from the outer cover of LERF Basins after successful repair is necessary to prevent future precipitation collection from containing listed waste constituents. This process will be implemented when a LERF Basin cover needs to remove listed waste codes. LERF cover decontamination is accomplished under the following process. Prior to repairing the cover, any water on the cover in the vicinity of the leaking or damaged section, if present, will be removed. A 5' diameter around the hole will be rinsed with water sprays or baths of sufficient volume and agitation (e.g., mops, rags, brushes) to remove dangerous contaminants from the cover surface. Decontamination will be considered successful after rinse water is removed and visual inspection of the cover surface appears free from waste. Weathering consisting of light shadows, slight streaks, or minor discoloration may be present. All waste generated during the decontamination process will be managed and handled according to the applicable generator standard requirements (WAC 173-303-170 through WAC 173-303-230) or within a 200 Area ETF permitted area."

WAC 173-303-830 Modification Class	Class 1	Class 1	Class 2	Class 3
Please mark the Modification Class:		X		

Enter relevant WAC 173-303-830, Appendix I Modification citation number: WAC 173-303-830(d)(i) Other modifications.

WAC 173-303-830(d)(i) Other modifications. In the case of modifications not explicitly listed in Appendix I of this section, the permittee may submit a Class 3 modification request to the department, or he or she may request a determination by the director that the modification should be reviewed and approved as a Class 1 or Class 2 modification. If the permittee requests that the modification be classified as a Class 1 or 2 modification, he or she must provide the department with the necessary information to support the requested classification.

Modification Approved: ☒ Yes ☐ No

Reason for Denial: Approved with changes to the PCN form, as agreed to by the Permittees.

Approved by Ecology:

E. J. Holbrook

2025.11.20 13:23:33 -08'00'

Date

Revision Instructions:

Revise the Permit Conditions and Addendums below to incorporate the changes shown herein:

- Addendum B, Waste Analysis Plan

LIQUID EFFLUENT RETENTION FACILITY & 200 AREA EFFLUENT TREATMENT FACILITY
ADDENDUM B
WASTE ANALYSIS PLAN
CHANGE CONTROL LOG

Change Control Logs ensure that changes to this unit are performed in a methodical, controlled, coordinated, and transparent manner. Each unit addendum will have its own change control log with a modification history table. The "**Modification Number**" represents Ecology's method for tracking the different versions of the permit. This log will serve as an up to date record of modifications and version history of the unit.

Modification History Table

Modification Date	Modification Number
08/05/2022	8C.2021.14F
06/30/2022	8C.2022.1F
02/28/2022	8C.2021.10F
09/23/2021	8C.2021.2F
06/28/2021	8C.2021.7F
03/10/2021	8C.2020.8F
05/19/2020	8C.2020.6F
12/7/2018	PCN-LERF/ETF-2018-01 (8C.2018.Q4)
01/23/2018	PCN-LERF/ETF-2017-01 (8C.2018.Q1)
10/25/2017	8C.2017.3F
08/25/2015	8C.2016.Q2

This page intentionally left blank.

LIQUID EFFLUENT RETENTION FACILITY & 200 AREA EFFLUENT TREATMENT FACILITY
ADDENDUM B
WASTE ANALYSIS PLAN

1
2
3
4 This page intentionally left blank.
5

ADDENDUM B
WASTE ANALYSIS PLAN

TABLE OF CONTENTS

B. Waste Analysis Plan 5
B.1 Introduction 5
B.1.1 Liquid Effluent Retention Facility and 200 Area Effluent Treatment Facility Description 6
B.1.2 Sources of Aqueous Waste 8
B.2 Influent Waste Acceptance Process 9
B.2.1 Waste Information 9
B.2.2 Waste Management Decision Process 11
B.2.3 Periodic Review Process 16
B.2.4 Record/Information and Decision 16
B.3 Special Management Requirements 19
B.3.1 Land Disposal Restriction Compliance at Liquid Effluent Retention Facility 19
B.3.2 Listed Waste Code Decontamination Process 19
B.4 Influent Aqueous Waste Sampling and Analysis 21
B.4.1 Sampling Procedures 21
B.4.2 Analytical Rationale 22
B.5 Treated Effluent Sampling and Analysis 23
B.5.1 Rationale for Effluent Analysis Parameter Selection 24
B.5.2 Effluent Sampling Strategy: Methods, Location, Analyses, and Frequency 24
B.6 Effluent Treatment Facility Generated Waste Sampling and Analysis 25
B.6.1 Secondary Waste Generated from Treatment Processes 25
B.6.2 Operations and Maintenance Waste Generated at the 200 Area Effluent Treatment Facility 29
B.6.3 Other Waste Generated at the 200 Area Effluent Treatment Facility 30
B.7 Quality Assurance/Quality Control 31
B.7.1 Project Management 31
B.7.2 Data Quality Parameters and Criteria 32
B.7.3 Data Generation and Acquisition 34
B.7.4 Assessment and Oversight 35
B.7.5 Verification and Validation of Analytical Data 36
B.8 Analytical Methods, Sample Containers, Preservative Methods, and Holding Times 36

TABLES

Table B-1 General Limits for Liner Compatibility 17
Table B-2 Waste Acceptance Criteria 18
Table B-3 Listed Waste Decontamination Constituents and Performance Standards 20
Table B-4 Target Parameters for Influent Aqueous Waste Analyses 23
Table B-5 Rationale for Parameters to be Monitored in Treated Effluent 27
Table B-6 200 Area Effluent Treatment Facility Generated Waste - Sampling and Analysis 30
Table B-7 Sample and Analysis Criteria for Influent Aqueous Waste and Treated Effluent 36
Table B-8 Sample Containers, Preservative Methods, and Holding Times for 200 Area Effluent Treatment Facility Generated Waste 41

B. WASTE ANALYSIS PLAN

B.1 Introduction

In accordance with the regulations set forth in the Washington State Department of Ecology (Ecology) Dangerous Waste Regulations, Washington Administrative Code (WAC) 173-303-300, this Waste Analysis Plan (WAP) has been prepared for operation of the Liquid Effluent Retention Facility (LERF) and the 200 Area Effluent Treatment Facility (200 Area ETF) that are located in the 200 East Area on the Hanford Site, Richland, Washington.

The purpose of this WAP is to ensure that adequate knowledge as defined in WAC 173-303-040, is obtained for dangerous and/or mixed waste accepted by and managed in LERF and 200 Area ETF. This WAP documents the sampling and analytical methods, and describes the procedures used to obtain this knowledge. This WAP also documents the requirements for generators sending aqueous waste to the LERF or 200 Area ETF for treatment. Throughout this WAP, the term generator includes any Hanford Site source, including Treatment, Storage, and Disposal (TSD) units, whose process produces an aqueous waste.

LERF consists of four surface impoundments (Basins 41 through 44), which provide treatment and storage. The 200 Area ETF includes tank systems, which provides treatment and storage, and container management areas, which provides container storage and treatment. Additionally, this WAP discusses the sampling and analytical methods for the treated effluent (treated aqueous waste) that is discharged from 200 Area ETF as a non-dangerous, delisted waste to the State Approved Land Disposal Site (SALDS), and secondary waste that is stored and treated at 200 Area ETF. Specifically, the WAP contains sampling and analysis requirements including quality assurance/quality control (QA/QC) requirements, for the following:

- **Influent Waste Acceptance Process** - determines the acceptability of a particular aqueous waste at the LERF or 200 Area ETF pursuant to applicable permit conditions, regulatory requirements, and operating capabilities prior to acceptance of the waste at the LERF or 200 Area ETF for treatment or storage. This includes documenting that wastes accepted for treatment at 200 Area ETF are within the treatability envelope required by the Final Delisting 200 Area ETF, Permit Condition 1.a.i. Refer to Section B.2.
- **Special Management Requirements** - identifies the special management requirements for aqueous wastes managed in the LERF or 200 Area ETF. Refer to Section B.3.
- **Influent Aqueous Waste Sampling and Analysis** - describes influent sampling and analyses used to characterize an influent aqueous waste to ensure proper management of the waste and for compliance with the special management requirements. Also includes rationale for analyses. Refer to Section B.4.
- **Treated Effluent Sampling and Analysis** - describes sampling and analyses of treated effluent (i.e., treated aqueous waste) for compliance with Discharge Permit Number ST0004500; and Final Delisting 200 Area ETF [40 Code of Federal Regulations (CFR) 261, Appendix IX, Table 2 incorporated by reference by WAC 173-303-910(3) and the corresponding State Final Delisting issued pursuant to WAC 173-303-910(3) limits]. Also includes rationale for analyses. Refer to Section B.5.
- **200 Area ETF Generated Waste Sampling and Analysis** - describes the sampling and analyses used to characterize the secondary waste streams generated from the treatment process and to characterize waste generated from maintenance and operations activities. Also includes rationale for analyses. Characterization and designation of wastes generated from maintenance and operations activities are conducted pursuant to WAC 173-303-170 and are not subject to the permit requirements of WAC 173-303-800. These descriptions are included in this WAP for

purposes of completeness, but are not enforceable conditions of this WAP or the Permit. Refer to Section B.6.

- **Quality Assurance and Quality Control** - ensures the accuracy and precision of sampling and analysis activities. Refer to Section B.7.

This WAP meets the specific requirements of the following:

- Land Disposal Restrictions (LDR) Treatment Exemption for the LERF under 40 CFR 268.4, U.S. Environmental Protection Agency (EPA), December 6, 1994 Memo, Mr. Dan Duncan, EPA to Ms. June Hennig, U.S. Department of Energy (DOE), "Liquid Effluent Retention Facility (LERF) Land Disposal Restrictions Treatment Exemption – Regulatory Interpretation."
- Final Delisting 200 Area ETF [40 CFR 261, Appendix IX, Table 2 incorporated by reference by WAC 173-303-910(3)].
- Corresponding State Final Delisting issued pursuant to WAC 173-303-910(3).
- Discharge Permit Number ST0004500, as amended.
- Hanford Facility Dangerous Waste Permit (Permit) WA7890008967, as amended.

Some permit requirements from Discharge Permit Number ST0004500 are included in this WAP for completeness. In addition, generator requirements for designation of wastes generated by LERF and 200 Area ETF from operation and maintenance activities are also included in this WAP for completeness. The Discharge Permit Number ST0004500 requirements are not within the scope of Resource Conservation and Recovery Act (RCRA) or WAC 173-303 or subject to the permit requirements of WAC 173-303-800. Therefore, revisions of this WAP that are not governed by the requirements of WAC 173-303 will not be considered as a modification subject to review or approval by Ecology. Any other revisions to this WAP will be incorporated through the Permit modification process as necessary to demonstrate compliance with requirements of this Permit, including Permit Conditions I.E.7 and I.E.8.

B.1.1 Liquid Effluent Retention Facility and 200 Area Effluent Treatment Facility Description

The LERF and 200 Area ETF comprise an aqueous waste treatment system located in the 200 East Area. Both LERF and 200 Area ETF may receive aqueous waste through several inlets. 200 Area ETF can receive aqueous waste through three inlets. First, 200 Area ETF can receive aqueous waste directly from the LERF. Second, aqueous waste can be transferred from the 2025ED Load-In Station to 200 Area ETF. Third, aqueous waste can be transferred from containers (e.g., carboys, drums) to the 200 Area ETF through either the Secondary Waste Receiving Tanks or the Concentrate Tanks.

The LERF can receive aqueous waste through five inlets. First, aqueous waste can be transferred to LERF through a dedicated pipeline from the 200 West Area. Second, aqueous waste can be transferred through a pipeline that connects LERF with the 242-A Evaporator and Waste Treatment and Immobilization Plant (WTP). Third, aqueous waste also can be transferred to LERF from pipelines that connect LERF to either Load-In Station, or ETF through a distribution point located at the surge tank berm. Fourth, aqueous waste can be transferred into LERF through a series of sample ports located at each basin. Finally, aqueous waste can be transferred through a pipeline that connects LERF with the WTP.

The LERF consists of four lined surface impoundments. Aqueous waste from LERF is pumped to 200 Area ETF through a double-walled fiberglass pipeline. The pipeline is equipped with leak detection located in the annulus between the inner and outer pipes. Basin 41 is equipped with eight available sample risers constructed of 6-inch-perforated pipe, and a ninth riser that contains liquid level instrumentation. Basins 42, 43, and 44 are equipped with six available sample risers constructed of 6-inch-perforated pipe. A seventh sample riser in Basins 42, 43, and 44 is dedicated to influent waste receipt piping, and an eighth riser in these basins contains liquid level instrumentation. Each riser extends along the sides of

each basin from the top to the bottom of the basin. Detailed information on the construction and operation of the LERF is provided in Addendum C, "Process Information."

200 Area ETF is designed to treat the contaminants anticipated in process condensate from the 242-A Evaporator, WTP-EMF (Effluent Management Facility), and other aqueous wastes from the Hanford Site. Section B.1.2 provides more information on the sources of these wastes.

The capabilities of 200 Area ETF were confirmed through pilot plant testing. A pilot plant was used to test surrogate solutions that contained constituents of concern anticipated in aqueous wastes on the Hanford Site. The pilot plant testing served as the basis for a demonstration of the treatment capabilities of 200 Area ETF in the *200 Area Effluent Treatment Facility Delisting Petition* (DOE/RL-92-72).

200 Area ETF consists of a primary and a secondary treatment train (Figure C-4 and C-5 in Addendum C). The primary treatment train removes or destroys dangerous and mixed waste components from the aqueous waste.

In the secondary treatment train, the waste components are concentrated and either dried into a powder or managed as brine from the concentrate tanks. Dry powder waste is containerized, and transferred to an authorized dangerous waste facility, or the Environmental Restoration Disposal Facility (ERDF). Brine waste can be transferred into containers using the brine loadout system for treatment at an authorized dangerous waste facility.

Each treatment train consists of a series of operations. The primary treatment train includes the following:

- Surge tank.
- Filtration.
- Carbon dioxide (CO2) removal skid.
- Ultraviolet light oxidation (UV/OX).
- pH adjustment.
- Hydrogen peroxide decomposition.
- Degasification column.
- Reverse osmosis (RO).
- Ion exchange.
- Steam stripping.
- Verification.

The secondary treatment train uses the following:

- Secondary waste receiving.
- Evaporation (with mechanical vapor recompression).
- Concentrate (brine) staging.
- Thin film drying.
- Brine Loadout.
- Container handling.
- Supporting systems.
- Acetonitrile distillate load-out.

The secondary waste treatment system typically receives and processes by-products generated from the primary treatment train. However, in an alternate operating scenario, some aqueous wastes may be fed to the secondary treatment train before the primary treatment train.

The treated effluent from the primary treatment train is contained in verification tanks where the effluent is sampled to confirm that the effluent meets the Delisting criteria. Under 40 CFR 261, Appendix IX, Table 2 incorporated by reference by WAC 173-303-910(3), the treated effluent from 200 Area ETF is considered a delisted waste; that is, the treated effluent is no longer a listed dangerous waste subject to the hazardous waste management requirements of RCRA provided that the Delisting criteria are satisfied and the treated effluent does not exhibit a dangerous characteristic. The treated effluent is discharged under the Discharge Permit Number ST0004500 as a non-dangerous, delisted waste to the SALDS, located in the 600 Area, north of the 200 West Area. A portion of the treated wastewater from the Verification Tanks is recycled as service water throughout the facility; for example, it is used to dilute bulk acid and caustic to meet processing needs, thereby reducing the demand for process water. When using the stream stripper, the primary treatment train generates a secondary waste stream of acetonitrile distillate. The acetonitrile distillate does not meet Delisting and is not discharged to SALDS. The acetonitrile distillate is sent to the acetonitrile distillate storage tanks or containerized in the Acetonitrile Distillate Loadout Facility and stored in the acetonitrile tote storage area until sent off site for treatment.

B.1.2 Sources of Aqueous Waste

200 Area ETF was intended and designed to treat a variety of mixed wastes. As cleanup activities at Hanford progress, many of the aqueous wastes generated from site remediation and waste management activities are sent to the LERF and 200 Area ETF for treatment and storage. A brief discussion of waste streams that may be managed by LERF and 200 Area ETF in the future may be found in the *200 Area Effluent Treatment Facility Delisting Petition* (DOE/RL-92-72). Prior to management of any new waste streams, it may be necessary to modify this WAP through the permit modification process to ensure that adequate knowledge of such new waste streams is available prior to management of them in LERF and 200 Area ETF.

The 242-A process condensate is a dangerous waste because it is derived from a listed, dangerous waste stored in the Double-Shell Tank (DST) System. The DST waste is transferred to the 242-A Evaporator where the waste is concentrated through an evaporation process. The concentrated slurry waste is returned to the DST System, and the evaporated portion of the waste is recondensed, collected, and transferred as process condensate to the LERF.

The WTP process condensate is a dangerous waste because it is derived from a listed, dangerous waste stored in the DST System. The DST waste is transferred to WTP for vitrification. Waste derived from the vitrification process is transferred to the EMF for additional treatment. The secondary waste from EMF is transferred to LERF for treatment at ETF. Aqueous waste from the analytical laboratory is also transferred to LERF.

Other aqueous wastes that are acceptable for treatment and/or storage at the LERF and 200 Area ETF include, but are not limited to the following Hanford wastes:

- Contaminated groundwater from pump-and-treat remediation activities such as groundwater from the 200-UP-1 Operable Unit.
- Purgewater from groundwater monitoring activities.
- Water from deactivation activities, such as water from the spent fuel storage basins at deactivated reactors (e.g., N Reactor).
- Laboratory aqueous waste from unused samples and sample analyses.
- Leachates from landfills, such as the Low-Level Burial Grounds Trenches 31 and 34, and the Integrated Disposal Facility (IDF). 200 Area ETF remains a backup treatment capability for the ERDF leachate.

- Any dilute waste, which may be accepted for treatment and within the scope of wastewaters that are delisted under terms of the revised Delisting [40 CFR 261, Appendix IX, Table 2 incorporated by reference by WAC 173-303-910(3)].

Most of these aqueous wastes are accumulated in batches in a LERF Basin for interim storage and treatment through pH and flow equalization before final treatment in 200 Area ETF. However, some aqueous wastes, such as 200-UP-1 Groundwater, may be treated on a flow-through basis in LERF enroute to 200 Area ETF for final treatment. The constituents in these aqueous wastes are common to the Hanford Site and were considered in pilot plant testing or in vendor tests, either as a constituent or as a family of constituents. According to the Final Delisting 200 Area ETF, and Permit Condition III.3.B.7, all wastes accepted for treatment at 200 Area ETF must be within a specified treatability envelope that ensures that wastes will be within the treatment capability of 200 Area ETF.

B.2 Influent Waste Acceptance Process

Throughout the acceptance process, there are specific criteria required for an influent waste (i.e., aqueous waste) to be accepted at the LERF and/or 200 Area ETF. These criteria are identified in the following sections and summarized in Table B-2. The process of accepting a waste into the LERF and 200 Area ETF systems involves a series of steps, as follows.

- **Waste Information:** The generator of an aqueous waste works with LERF and 200 Area ETF personnel to provide characterization data of the waste stream (Section B.2.1).
- **Waste Management Decision Process:** LERF and 200 Area ETF management decision is based on a case-by-case evaluation of whether an aqueous waste stream is acceptable for treatment or storage at LERF and the 200 Area ETF. The evaluation has two categories:
  - **Regulatory Acceptability:** A review to determine if there are any, regulatory concerns that would prohibit the storage or treatment of an aqueous waste in the LERF or 200 Area ETF; e.g., treatment would meet permit conditions that would comply with applicable regulations.
  - **Operational Acceptability:** An evaluation to determine if there are any operational concerns that would prohibit the storage or treatment of an aqueous waste in the LERF or 200 Area ETF and storage of treatment residuals; e.g., determine treatability and compatibility or safety considerations (Section B.2.2.2).

B.2.1 Waste Information

When an aqueous waste stream is identified for treatment or storage in the LERF or 200 Area ETF, the generator is required to characterize the waste stream according to the requirements in Section B.2.1.1 and document the results of characterization on an aqueous waste profile sheet. This requirement is the first waste acceptance criterion.

The LERF and 200 Area ETF personnel work with the generators to ensure that the necessary information is collected for the characterization of a waste stream (i.e., the appropriate analyses or adequate knowledge), and that the information provided on the waste profile sheet is complete. The completed waste profile sheet is maintained in the LERF and 200 Area ETF Operating Record according to Permit Condition II.I.1.j.

B.2.1.1 Waste Characterization

Because the constituents in the individual aqueous waste streams vary, each waste stream is characterized and evaluated for acceptability on a case-by-case basis. The generator is required to designate an aqueous waste, which generally will be based on analytical data. However, a generator may use knowledge to substantiate the waste designation, or for general characterization information. Examples of acceptable knowledge include the following:

- Documented data or information on processes similar to that which generated the aqueous waste stream.
- Information/documentation that the waste stream is from specific, well documented processes, e.g., F-listed wastes.
- Information/documentation that sampling/analyzing a waste stream would pose health and safety risks to personnel.
- Information/documentation that the waste stream does not lend itself to collecting a laboratory sample for example, wastewater collected (e.g., sump, tank) where the source water characterization is documented. Typically, these circumstances occur at decommissioned buildings or locations, not at operating units.

When a generator performs characterization of a dangerous and/or mixed waste stream based on knowledge, LERF and 200 Area ETF personnel review the knowledge as part of the waste acceptance process to ensure the knowledge satisfies the definition of *Knowledge* in WAC 173-303-040. Specifically, LERF and 200 Area ETF personnel review the generator's processes to verify the integrity of the knowledge, and determine whether the knowledge is current and consistent with requirements of this WAP. LERF and 200 Area ETF management or their designee determines the final decision on the adequacy of the knowledge. The persons reviewing generator process knowledge and those making decisions on the adequacy of knowledge are trained according to the requirements of Addendum G, "Personnel Training."

The requirements of 40 CFR 264, Subpart BB (WAC 173-303-691) are not applicable to the LERF or 200 Area ETF because waste streams with concentrations of organics equal to or higher than 10 percent are not accepted at the LERF or 200 Area ETF in order to comply with the Delisting requirements. The generator is responsible for providing analytical data and/or knowledge that the influent waste stream is below 10 percent total organic content.

The generator is responsible for providing analytical data and/or knowledge that the influent aqueous waste meets the mixed waste exemption to implement Subpart CC emission standards [WAC 173-303-300(5)(i)(i), WAC 173-303-300(5)(i)(ii)]. The LERF Basins rely on the mixed waste exemption to implement Subpart CC emission standards [WAC 173-303-692(1)(b)(vi)]. Should the LERF Basins receive non-radioactive dangerous waste, the volatile organic concentration at the point of waste origination shall be less than 500 parts per million (ppm) by weight [40 CFR 264.1082(c)(1)]. These waste streams may be combined with mixed waste in the LERF Basins without affecting the use of the mixed waste exemption because the non-radioactive dangerous waste streams would be below 500 ppm by weight volatile organic concentration. Non-dangerous radioactive waste, state-only dangerous waste, and non-radioactive/non-dangerous waste may also be combined with mixed waste in the LERF Basins without affecting the use of the mixed waste exemption.

The generator is also responsible for identifying LDRs treatment standards applicable to the influent aqueous waste as part of the characterization, as required under 40 CFR 268.40 incorporated by reference by WAC 173-303-140. Because the 200 Area ETF main treatment train is a Clean Water Act, equivalent treatment unit [40 CFR 268.37(a)] incorporated by reference by WAC 173-303-140, generators are not required to identify underlying hazardous constituents for characteristic wastes pursuant to 40 CFR 268.9, incorporated by reference by WAC 173-303-140, for wastewaters (i.e., <1 percent total suspended solids and <1 percent total organic carbon). The 200 Area ETF secondary waste (e.g., brine or powder) reflects a change in LDR treatability group (i.e., wastewater to non-wastewater) so there is a new LDR point of generation, at which point any characteristic and associated underlying hazardous constituents must be identified. Therefore, generators of a non-wastewater may be required to identify underlying hazardous constituents for characteristic wastes pursuant to 40 CFR 268.9, incorporated by reference by WAC 173-303-140.

When analyzing an aqueous waste stream for LERF and 200 Area ETF waste acceptance characterization, a generator is required to use the target list of parameters identified in Table B-4, of this WAP. This requirement is in addition to any analysis required for purposes of designation under WAC 173-303-070. These data are used by LERF and 200 Area ETF to verify the treatability of an aqueous waste stream, and to develop a treatment plan for the waste after acceptance. Refer to Table B-7, for the corresponding analytical methods. The generator may use knowledge in lieu of some analyses, as determined by LERF and 200 Area ETF management or their designee, if the knowledge satisfies the definition of *Knowledge* in WAC 173-303-040. For example if a generator provides information that the process generating an aqueous waste does not include or involve organic chemicals, analyses for organic compounds likely would not be required. Additional analyses could be required if historical information and/or knowledge indicate that an aqueous waste contains constituents not included in the target list of parameters.

The characterization and historical information are documented in the waste profile sheet, which is discussed in the following section and is part of the LERF and 200 Area ETF Operating Record according to Permit Condition II.I.

B.2.1.2 Aqueous Waste Profile Sheet

The waste profile sheet documents the characterization of each new aqueous waste stream. The profile includes a detailed description of the source, volume, waste designation and applicable LDR treatment standards, and physical nature (wastewater or non-wastewater) of the aqueous waste. For an aqueous waste to be accepted for treatment or storage in the LERF or 200 Area ETF, each new waste stream generator is required to complete and provide this form to LERF and 200 Area ETF management. Each generator also is required to provide the analytical data and/or knowledge used to designate the aqueous waste stream according to WAC 173-303-070 and to determine the chemical and physical nature of the waste.

The LERF and 200 Area ETF management determine whether the information on the waste profile sheet is sufficient according to the criteria above. The LERF and 200 Area ETF management use this information to evaluate the acceptability of the aqueous waste stream for storage and treatment in the LERF and 200 Area ETF, and to determine if the secondary waste generated from treatment is acceptable for storage at the 200 Area ETF and has a defined path forward to final disposal.

B.2.2 Waste Management Decision Process

All aqueous waste under consideration for acceptance must be characterized using analytical data and/or knowledge. This information is used to determine the acceptability of an aqueous waste stream. The LERF and 200 Area ETF Facility Manager or their designee is responsible for making the decision to accept or reject an aqueous waste stream. The management decision to accept any aqueous waste stream is based on an evaluation of regulatory acceptability and operational acceptability. Each evaluation uses acceptance criteria, which were developed to ensure that an aqueous waste is managed in a safe, environmentally sound, and in compliance with this Permit. The following sections provide detail on the acceptance evaluation and the acceptance criteria.

An aqueous waste stream could be rejected for one of the following reasons:

- The paperwork and/or laboratory analyses from the generator are insufficient.
- Discrepancies with the regulatory and operational acceptance criteria cannot be reconciled, including:
    - An aqueous waste, which is not allowed under the current Final Delisting 200 Area ETF, and LERF and 200 Area ETF management elect not to pursue an amendment, or the Final Delisting 200 Area ETF cannot be amended (Section B.2.2.1).
    - An aqueous waste is incompatible with LERF liner materials or with other aqueous waste in LERF and no other management method is available (Section B.2.2.3.1).

- An aqueous waste, which is not allowed under the Subpart CC mixed waste exemption as described in Section B.2.1.1.

- Adequate storage or treatment capacity is not available.

B.2.2.1 Regulatory Acceptability

Each aqueous waste stream is evaluated on a case-by-case basis to determine if there are any regulatory concerns that would preclude the storage or treatment of a waste in the LERF or 200 Area ETF based on the criteria in Sections B.2.2.1.1. Before an aqueous waste can be stored or treated in either the LERF or 200 Area ETF, the waste designation must be determined. Information on the waste designation of an aqueous waste is documented in the waste profile sheet. This information is used to confirm that treating or storing the aqueous waste in the LERF or 200 Area ETF is allowed under and in compliance with WAC 173-303, Permit (WA7890008967), Final Delisting 200 Area ETF in 40 CFR 261, Appendix IX, Table 2 incorporated by reference by WAC 173-303-910(3), and the corresponding State-Issued Delisting for 200 Area ETF.

B.2.2.1.1 Dangerous Waste Regulations, State and Federal Delisting Actions, and Permits

Before an aqueous waste stream is sent to the LERF or 200 Area ETF, the generator will characterize and designate the stream with the appropriate dangerous/hazardous waste numbers according to WAC 173-303-070. Addendum A, the Final Delisting 200 Area ETF and the corresponding State-Issued Delisting identify the specific waste numbers for dangerous/mixed waste that can be managed in the LERF and 200 Area ETF. Dangerous waste designated with waste numbers not specified in these documents cannot be treated or stored in the LERF or 200 Area ETF, unless the documents are appropriately modified.

Additionally, aqueous wastes designated with listed waste numbers identified in the Final Delisting 200 Area ETF and the corresponding State-Issued Delisting will be managed in accordance with the conditions of the Delisting, or an amended Delisting.

B.2.2.2 Operational Acceptability

Because the operating configuration or operating parameters at the LERF and 200 Area ETF can be adjusted or modified, most aqueous waste streams generated on the Hanford Site can be effectively treated to below Delisting and Discharge Permit limits. Because of this flexibility, it would be impractical to define numerical acceptance or decision limits. Such limits would constrain the acceptance of appropriate aqueous waste streams for treatment at the LERF and 200 Area ETF. The versatility of the LERF and 200 Area ETF is better explained in the following examples:

- The typical operating configuration of 200 Area ETF is to process an aqueous waste through the UV/OX unit first, followed by the RO unit. However, high concentrations of nitrates may interfere with the performance of the UV/OX. In this case, 200 Area ETF could be configured to process the waste in the RO unit prior to the UV/OX unit.

- For a waste containing high carbonate/bi-carbonate that interfere with performance of the UV/OX unit, 200 Area ETF can be configured to operate the CO2 removal skid before the waste is treated in the UV/OX unit.

- For a waste stream with organic concentrations higher than the Delisting treatability envelope, the 200 Area ETF can be configured to operate the steam stripper to remove organics not effectively destroyed in the UV/OX unit.

- For a small volume aqueous waste with high concentrations of some anions and metals, the approach may be to first process the waste stream in the secondary treatment train. This approach would prevent premature fouling or scaling of the RO unit. The liquid portion (i.e., untreated overheads from 200 Area ETF evaporator and thin film dryer) would be sent to the primary treatment train.
- An aqueous waste with high concentrations of chlorides and fluorides may cause corrosion problems when concentrated in the secondary treatment train. One approach is to adjust the corrosion control measures in the secondary treatment train. An alternative may be to blend this aqueous waste in a LERF Basin with another aqueous waste, which has sufficient dissolved solids, such that the concentration of the chlorides in the secondary treatment train would not pose a corrosion concern.
- Some metal salts (e.g., barium sulfate) tend to scale the RO membranes. In this situation, descalants used in the treatment process may be increased.
- Any effluent that does not meet these limits in one pass through 200 Area ETF treatment process is recycled to 200 Area ETF for reprocessing.

There are some aqueous wastes, whose chemical and physical properties preclude that waste from being treated or stored at the LERF or 200 Area ETF. Accordingly, an aqueous waste is evaluated to determine if it is treatable, if it would impair the efficiency or integrity of the LERF or 200 Area ETF, and if it is compatible with materials in these units. This evaluation also determines if the aqueous waste is compatible with other aqueous wastes managed in the LERF.

The waste acceptance criteria in this category focus on determining treatability of an aqueous waste stream, and on determining any operational concerns that would prohibit the storage or treatment of an aqueous waste stream in the LERF or 200 Area ETF. The chemical and physical properties of an aqueous waste stream are determined as part of the waste characterization, and are documented on the waste profile sheet and compared to the design of the units to determine whether an aqueous waste stream is appropriate for storage and treatment in the LERF and 200 Area ETF. All decisions and supporting rationale and data will be documented in the LERF and 200 Area ETF Operating Record, according to Permit Condition II.I.

B.2.2.3 Special Requirements Pertaining to Land Disposal Restrictions

Containers of 200 Area ETF secondary waste are transferred to a treatment, storage, or final disposal unit, as appropriate (e.g., to the Central Waste Complex, ERDF). 200 Area ETF personnel provide the analytical characterization data and necessary process knowledge for the waste to be managed by the receiving staff, and the appropriate LDR documentation in accordance with Section B.6.1.1.

Generally, the operating parameters or operating configuration at the LERF or 200 Area ETF can be adjusted or modified to accommodate properties of the secondary waste. However, in those cases where a treatment process or operating configuration cannot be modified, the aqueous waste stream proposed for acceptance will not be accepted for treatment or storage at the LERF or 200 Area ETF. Additionally, an aqueous waste stream is evaluated for the potential to deposit solids in a LERF Basin (i.e., whether an aqueous waste contains sludge or could precipitate solids). This evaluation will also consider whether the blending or mixing of two or more aqueous waste streams will result in the formation of a precipitate. However, because the waste streams managed in the LERF and 200 Area ETF are generally dilute, the potential for mixing waste streams and forming a precipitate is low; no specific compatibility tests are performed. Filtration at the waste source could be required before acceptance into LERF. Waste streams with the potential to form precipitates in LERF or that cannot be blended with other waste streams to avoid precipitate formation are not accepted for treatment at LERF and 200 Area ETF. The 2025ED Load-In Station and 2025EG Backup Load-In Station have the ability to perform filtration on incoming waste streams going to both the LERF and Load In Station tank 59A-TK-1. See additional discussions of

precipitate formation and compliance with LDR requirements in Section B.3. Similar filtration requirements could apply to aqueous waste fed directly to 200 Area ETF without interim treatment in LERF.

To determine if an aqueous waste meets the criterion of treatability, specific information is required. Treatability of a waste stream is evaluated from characterization data provided by the generator as verified through the waste acceptance process, the 200 Area waste acceptance criteria, and the treatability envelope for the 200 Area ETF as documented in Tables C-1 and C-2 of the November 29, 2001 delisting petition. Generators will also provide characterization data to identify those physical and chemical properties that would interfere with, or foul 200 Area ETF treatment process in consultation with LERF and 200 Area ETF representatives. In some instances, knowledge that meets the definition of *Knowledge* in WAC 173-303-040 is used for purposes of identifying a chemical or physical property that would be of concern. For example, the generator could provide knowledge that the stream has two phases (an oily phase and an aqueous phase). In this case, if the generator could not physically separate the two phases, the aqueous waste stream would be rejected because the oily phase could compromise some of the treatment equipment. Typically, analyses for the following parameters are required to evaluate treatability and operational concerns:

- Total dissolved solids.
- Total organic carbon.
- Total suspended solids.
- Specific conductivity.
- pH.
- Acetonitrile.
- Alkalinity.
- Ammonia.
- Barium.
- Calcium.
- Carbonate/Bi-carbonate.
- Chloride.
- Fluoride.
- Iron.
- Magnesium.
- Nitrate.
- Nitrite.
- Phosphate.
- Potassium.
- Silicon.
- Sodium.
- Sulfate.

These constituents are identified in Table B-2, which is the list of target analytes used for waste characterization and waste acceptance evaluation.

B.2.2.3.1 Compatibility

Corrosion Control. Because of the materials of construction used in 200 Area ETF, corrosion is generally not a concern with new aqueous waste streams. Additionally, these waste streams are managed in a manner that minimizes corrosion. To ensure that a waste will not compromise the integrity of 200 Area ETF tanks and process equipment, each waste stream is assessed for its corrosion potential as part of the compatibility evaluation. This assessment usually focuses on chloride and fluoride concentrations; however, the chemistry of each new waste also is evaluated for other parameters that could cause corrosion.

Compatibility with LERF Liners and Piping. As part of the acceptance process, the criteria of compatibility with the LERF liner materials are evaluated for each aqueous waste stream. This evaluation is performed using knowledge (as defined by WAC 173-303-040) of constituent concentrations in the aqueous waste stream or using constituent concentrations obtained by analyzing the waste stream for the constituents identified in Table B-1 using the analytical methods for these constituents in Section B.8. Then, the constituent concentrations in the waste stream are compared to the decision criteria in Table B-1. If all constituent concentrations are below the decision criteria, then the waste stream is considered compatible with the LERF liners and may be accepted for treatment. Otherwise, the waste stream is considered incompatible with the LERF liners, and it cannot be accepted for treatment in the LERF Basins. However, a waste stream may still be acceptable for treatment in 200 Area ETF if it is fed directly to 200 Area ETF, bypassing the LERF Basins. Results of this evaluation are documented in the, LERF and 200 Area ETF Operating Record according to Permit Condition II.I. The rational for

establishing the liner compatibility constituents and decision criteria in Table B-1 is as follows: The high-density polyethylene liners in the LERF Basins potentially are vulnerable to the presence of certain constituents that might be present in some aqueous waste. Using EPA SW-846, Method 9090, the liner materials were tested to evaluate compatibility between aqueous waste stored in the LERF and synthetic liner components. Based on the data from the compatibility test and vendor data on the liner materials, several constituents and parameters were identified as potentially harmful (at high concentrations) to the integrity of the liners. From these data and the application of safety factors, concentration limits in Table B-1 were established.

The strategy for protecting the integrity of a LERF liner is to establish upfront that an aqueous waste is compatible before the waste is accepted into LERF. Characterization data on each new aqueous waste stream are compared to the limits outlined in Table B-1 to ensure compatibility with the LERF liner materials before acceptance into the LERF.

Before a waste stream is processed at the 242-A Evaporator, the generator reviews DST analytical data and a process condensate profile is developed to ensure the process condensate is compatible with the LERF liners. For flow through aqueous wastes like the 200-UP-1 Groundwater, characterization data will be obtained and reviewed every two years to ensure that liner compatibility is maintained. For WTP-EMF waste streams, the generator reviews WTP-EMF analytical data or acceptable process knowledge of the EMF effluent collection tanks to verify that the process condensate waste stream is compatible with the LERF liners.

The LERF or 200 Area ETF, or both, will receive hazardous aqueous waste generated at WTP. The waste will meet the waste acceptance criteria outlined in this Waste Analysis Plan (Addendum B). The LERF and 200 Area ETF allow process knowledge to be used in lieu of some analyses in instances where process knowledge is adequate, and a LERF or 200 Area ETF representative will work with a WTP representative to identify the waste acceptance criteria and analyses appropriate for liquid waste characterization.

The WTP will provide analysis data from representative samples to verify the effluent meets the LERF and 200 Area ETF Addendum B waste acceptance criteria. Additional sampling and analysis of EMF effluent will be performed periodically per Section B.2.3, and in the event of a process upset, change in effluent source, compliance purposes, data loss, or as agreed to by WTP and LERF and 200 Area ETF.

The WTP will perform online monitoring of the effluent flow rate, pH, and conductivity, and the data will be transmitted to the LERF Instrument Building. The real-time data will be transmitted to the 200 Area ETF Control Room.

In some instances, knowledge may be adequate to determine that an aqueous waste is compatible with the LERF liners. When knowledge is used, it must satisfy the definition of *Knowledge* in WAC 173-303-040. In those instances where knowledge is adequate, the waste characterization would likely not require analysis for these parameters and constituents. Storm water is an example where knowledge is adequate to determine that this aqueous waste is compatible with the LERF liners.

Compatibility with Other Waste. Some aqueous wastes, especially small volume streams, are accumulated in the LERF with other aqueous waste. Before acceptance into the LERF, the aqueous waste stream is evaluated for its compatibility with the resident aqueous waste(s). The evaluation focuses on the potential for an aqueous waste to react with another waste (40 CFR 264, Appendix V, *Examples of Potentially Incompatible Wastes*) including formation of any precipitate in the LERF Basins.

However, the potential for problems associated with commingling aqueous wastes is very low due to the dilute nature of the wastes; this evaluation confirms the compatibility of two or more aqueous wastes from different sources. Compatibility is determined by evaluating parameters such as pH, ammonia, and chloride. No specific analytical test for compatibility is performed.

If it is determined that an aqueous waste stream is incompatible with other aqueous waste streams, alternate management scenarios are available. For example, another LERF Basin that contains a compatible aqueous waste(s) might be used, or the aqueous waste stream might be fed directly into 200 Area ETF for treatment. In any case, potentially incompatible waste streams are not mixed, and all aqueous waste is managed in a way that precludes a reaction, degradation of the liner, or interference with 200 Area ETF treatment process.

B.2.3 Periodic Review Process

In accordance with WAC 173-303-300(4)(a), an influent aqueous waste will be periodically reviewed as necessary to ensure that the characterization is accurate and current. At a minimum, an aqueous waste stream will be reviewed in the following situations.

- The LERF and 200 Area ETF management have been notified, or have reason to believe that the process generating the waste has changed.
- The LERF and 200 Area ETF management note an increase or decrease in the concentration of a constituent in an aqueous waste stream, beyond the range of concentrations that was described or predicted in the waste characterization.
- Waste streams will be reviewed every two years.

In these situations, LERF and 200 Area ETF management will review the available information. If existing analytical information is not sufficient, the generator may be asked to review and update the current waste characterization, to supply a new Waste Profile Sheet (WPS), or resample and reanalyze the aqueous waste, as necessary. Other situations that might require a reevaluation of a waste stream are discussed in the following sections.

B.2.4 Record/Information and Decision

The information and data collected throughout the acceptance process, and the evaluation and decision on whether to accept an influent aqueous waste stream for treatment or storage in the LERF or 200 Area ETF are documented as part of LERF and 200 Area ETF Operating Record pursuant to Permit Condition II.I. Specifically, the LERF and 200 Area ETF Operating Record contains the following components on a new influent aqueous waste stream:

- The signed WPS for each aqueous waste stream and analytical data.
- Knowledge used to characterize a dangerous/mixed waste (under WAC 173-303-090), and information supporting the adequacy of the knowledge.
- The evaluation on whether an aqueous waste stream meets the waste acceptance criteria, including:
  - The evaluation for regulatory acceptability including appropriate regulatory approvals.
  - The evaluation for LERF liner materials compatibility and for compatibility with other aqueous waste.

Table B-1 General Limits for Liner Compatibility

Chemical Family	Constituent(s) or Parameter(s)[1]	Limit[2] (sum of constituent concentrations)
Alcohol/Glycol	1-Butanol	500,000 mg/L 500,000 ppm
Alkanone[3]	Acetone	200,000 mg/L 200,000 ppm
Alkenone[4]	None targeted	N/A
Aromatic/Cyclic hydrocarbon	Acetophenone, benzene, carbozole, chrysene, cresol, di-n-octyl phthalate, diphenylamine, isophorone, pyridine, tetrahydrofuran	2,000 mg/L 2,000 ppm
Halogenated hydrocarbon	Arochlors, carbon tetrachloride, chloroform, hexachlorobenzene, lindane (gamma-BHC), hexachlorocyclopentadiene, methylene chloride, p-chloroaniline, tetrachloroethylene, 2,4,6-trichlorophenol	2,000 mg/L 2,000 ppm
Aliphatic hydrocarbon	None targeted	N/A
Ether	Dichloroisopropyl ether	2,000 mg/L 2,000 ppm
Other hydrocarbons	Acetontrile, carbon disulfide, n-nitrosodimethylamine, tributyl phosphate	2,000 mg/L 2,000 ppm
Oxidizers	None targeted	N/A
Acids, Bases, Salts	Ammonia, cyanide, anions, cations	100,000 mg/L 100,000 ppm
pH	pH	0.5 < pH < 13.0

[1]Analytical methods for the parameters and constituents are provided in Section B.8.

[2]Analytical data are evaluated using the following "sum of the fraction" technique. The individual constituent concentration is evaluated against the compatibility limit for its chemical family. The sum of the evaluations must be less than 1. pH is not part of this evaluation.

$$\sum_{n=1}^{i}\left(\frac{\text{Conc}_n}{\text{LIMIT}_n}\right) \le 1$$

The high concentration limits for alcohols/glycols and alkenones are included for performing the "sum of fraction" technique. The concentration of volatile organics must still be less than 10% (~100,000 ppm) per Section B.2.1.1.

[3]Ketone containing saturated alkyl group(s).

[4]Ketone containing unsaturated alkyl group(s).

Where "i" is the number of organic constituents detected.

mg/L = Milligrams per liter.

ppm = Parts per million.

N/A = Not applicable.

1

Table B-2 Waste Acceptance Criteria

General Criteria Category	Criteria Description
1. Characterization	A. Each generator must provide an aqueous waste profile.
	B. Each generator must designate the aqueous waste stream.
	C. Each generator must provide analytical data and/or knowledge.
2. Regulatory acceptability	A. The LERF and 200 Area ETF can store and treat influent aqueous wastes with waste numbers identified in Addendum A for the LERF and 200 Area ETF, and the Final Delisting 200 Area ETF, 40 CFR 261, Appendix IX, Table 2 incorporated by reference by WAC 173-303-910(3).
	B. The aqueous waste must comply with conditions of the Discharge Permit.
	C. An aqueous waste must comply with the conditions described in Section B.2.1.1 for Subpart CC compliance.
3. Operational acceptability	A. Determine whether an aqueous waste stream is treatable, considering: 1. Whether the removal and destruction efficiencies on the constituents of concern will be adequate to meet the Discharge Permit and Delisting levels. 2. Other treatability concerns; analyses for this evaluation may include: Total dissolved solids; Total organic carbon; Total suspended solids; Specific conductivity; Acetonitrile; Alkalinity; Ammonia; Barium; Calcium; Carbonate/bicarbonate; Chloride; Fluoride; Iron; Magnesium; Nitrate; Nitrite; Phosphate; Potassium; Silicon; Sodium; Sulfate; pH
	B. Determine whether an aqueous waste stream is compatible, considering: 1. Whether an aqueous waste stream presents corrosion concerns with respect to 200 Area ETF; analysis may include chloride and fluoride. 2. Whether an aqueous waste stream is compatible with LERF liner materials, compare characterization data to the liner compatibility limits (Table B-1). 3. Whether an aqueous waste stream is compatible with other aqueous waste(s), 40 CFR 264, Appendix V, comparison will be used.

1

B.3 Special Management Requirements

Special management requirements for aqueous wastes that are managed in the LERF or 200 Area ETF are discussed in the following section.

B.3.1 Land Disposal Restriction Compliance at Liquid Effluent Retention Facility

Because LERF provides treatment through flow and pH equalization, a surface impoundment treatment exemption from the LDRs was granted in accordance with 40 CFR 268.4, and WAC 173-303-040. This treatment exemption is subject to several conditions, including a requirement that the WAP address the sampling and analysis of the treatment "residue" [40 CFR 268.4(a)(2)(i) and WAC 173-303-300(5)(h)(i) and (ii)] to ensure the "residue" meets applicable treatment standards. Though the term "residue" is not specifically defined, this condition further requires that sampling must be designed to represent the "sludge and the supernatant" indicating that a residue may have a sludge (solid) and supernatant (liquid) component.

Solid residue is not anticipated to accumulate in a LERF Basin for the following reasons:

- Aqueous waste streams containing sludge would not be accepted into LERF under the acceptance criteria of treatability (Section B.2.2.3.1).
- No solid residue was reported from process condensate discharged to LERF in 1995.
- The LERF Basins are covered and all incoming air first passes through a breather filter.
- No precipitating or flocculating chemicals are used in flow and pH equalization.
- Multiple waste streams managed in a single LERF Basin are evaluated for the formation of precipitates. Wastes that would form precipitates are not accepted for treatment at LERF.

Therefore, the residue component subject to this condition is the supernatant (liquid component). Additionally, an aqueous waste stream is evaluated for the potential to deposit solids in a LERF Basin (i.e., an aqueous waste that contains suspended solids). If necessary, filtration at the waste source could be required before acceptance into LERF. Therefore, the residue component in LERF subject to this condition is the supernatant (liquid component). The contingency for removal of solids will be addressed during closure in Addendum H, "Closure Plan."

The conditions of the treatment exemption also require that treatment residues (i.e., aqueous wastes), which do not meet the LDR treatment standards "must be removed at least annually" [40 CFR 268.4(a)(2)(ii) incorporated by reference by WAC 173-303-140]. To address the conditions of this exemption, an influent aqueous waste is sampled and analyzed and the LDR status of the aqueous waste is established as part of the acceptance process. The LERF Basins are then managed such that any aqueous waste(s), which exceeds an LDR standard, is removed annually from a LERF Basin, except for a heel of approximately 3 feet. A heel is required to stabilize the LERF liner. The volume of the heel is approximately 550,000 gallons.

B.3.2 Listed Waste Code Decontamination Process

Decontamination of listed waste codes from the LERF Basins and the 200 Area ETF tank systems is necessary to maintain segregation of the waste streams processed through the 200 Area ETF. Based on the listed waste codes in the Part A (Addendum A), Table B-3 establishes the waste constituents and performance standards used in the decision on whether the dangerous waste management unit is decontaminated of a listed waste code(s).

Table B-3 Listed Waste Decontamination Constituents and Performance Standards

Listed Waste Code	Waste Constituent	CAS#	Decontamination Performance Standard* (µg/L)
F001	1,1,1-Trichloroethane	71-55-6	420,000
F002	Dichloromethane (Methylene Chloride)	75-09-2	255.6
F003	Acetone	67-64-1	2,400
F003	Methyl isobutyl ketone (Hexone) (4-Methyl-2-pentanone)	108-10-1	16,800
F004	Cresols (total)	1319-77-3	1,200
F005	Methyl ethyl ketone (2-butanone)	78-93-3	126,000
U210	Tetrachloroethylene	127-18-4	243.6
F039	Chromium**	7440-47-3	68

*Defined as 6 times the Health Based Limit calculated based on the methodology established for the 200 Area ETF Final Delisting.

**No F039 constituents are identified on the generator waste profile as a constituent to monitor under 40 CFR 268.7. Chromium is chosen as the constituent of concern in management of secondary treatment train evaporator concentrate.

In order to decontaminate a LERF Basin or the 200 Area ETF tank systems, the following minimum criteria must be met:

- A verification sample will be obtained for the applicable constituent(s) associated with the listed waste codes to be decontaminated prior to the decontamination flush.
- A calculation will be prepared to establish the volume of verification, potable, or raw water to be used as a flush to decontaminate the dangerous waste management unit to less-than-or-equal-to 80 percent of the decontamination performance standard.
- The minimum flush for any decontamination effort, including when the waste already meets the decontamination standard, will be based on reducing the decontamination performance standard in Table B-3 to less-than-or-equal-to 80 percent of that value.
- After the decontamination effort has been completed, Ecology will be notified. The notification will include the sample results, the calculation, the final volume of flush water used, and for LERF, the volume removed from the basin.

B.3.2.1 Decontaminate Liquid Effluent Retention Facility Basins of Listed Waste Codes

This procedure will be implemented when a LERF Basin needs to remove listed waste codes. A LERF Basin will be pumped down to the heel volume as defined in Section B.3.1. A volume adequate to obtain a representative heel sample will be pumped from the remaining LERF contents to the 200 Area ETF primary treatment train Surge Tank and sampled at the Surge Tank inlet for applicable constituents identified in Table B-3. When the heel sample result is already at or below the performance standards from Table B-3, the flush volume of verification, potable, or raw water will be 100,000 gallons. When the heel sample result exceeds the performance standards from Table B-3, the flush volume will be calculated to be the amount necessary to reduce the LERF heel concentration to less-than-or-equal-to 80 percent of the performance standard. A minimum flush volume of 100,000 gallons will be used when the calculated amount of flush volume is less than 100,000 gallons. Once flushed, the volume of verification, potable, or raw water used for the flush will be removed from the LERF Basin. Once the equivalent volume of waste is removed from the LERF Basin, the basin will be considered decontaminated of listed waste. If the

transfer of the waste out of the LERF basin poses an operational concern, Ecology will be notified to work an alternate solution, which may include leaving the flush water in the LERF Basin.

Decontamination of listed waste codes from the outer cover of LERF Basins after successful repair is necessary to prevent future precipitation collection from containing listed waste constituents. This process will be implemented when a LERF Basin cover needs to remove listed waste codes. LERF cover decontamination is accomplished under the following process. Prior to repairing the cover, any water on the cover in the vicinity of the leaking or damaged section, if present, will be removed. A 5' diameter around the hole will be rinsed with water sprays or baths of sufficient volume and agitation (e.g., mops, rags, brushes) to remove dangerous contaminants from the cover surface. Decontamination will be considered successful after rinse water is removed and visual inspection of the cover surface appears free from waste. Weathering consisting of light shadows, slight streaks, or minor discoloration may be present. All waste generated during the decontamination process will be managed and handled according to the applicable generator standard requirements (WAC 173-303-170 through WAC 173-303-230) or within a 200 Area ETF permitted area.

B.3.2.2 Decontaminate 200 Area Effluent Treatment Facility Tank Systems of Listed Waste Codes

This procedure will be implemented when ETF needs to remove listed waste codes after processing. At the beginning of 200 Area ETF processing, the waste transferred from LERF to the 200 Area ETF will be sampled from the Surge Tank inlet for applicable constituents identified in Table B-3. Sampling at the beginning of processing is necessary to prevent shut down of the 200 Area ETF while awaiting for sample results. The ETF tank systems will be decontaminated as follows: at a minimum, 150,000 gallons[1] of verification, potable, or raw water will be used to flush the Surge Tank and the primary treatment train. Once the Surge Tank is processed to heel, based on calculation, ETF will continue to operate the primary treatment train with verification, potable, or raw water, as needed, and will also continue to run the evaporator to ensure the constituent concentration will be below 80 percent of the performance standard in the secondary waste receiving tank. The concentrate tank will be flushed with verification, potable, or raw water and processed as necessary by calculation to ensure the heel will be less-than-or-equal-to 80 percent of the performance standard prior to ending processing. The thin film dryer or brine load-out piping will be flushed with verification, potable, or raw water prior to ending processing. By following this method, the listed waste codes from the previously completed processing will not apply to the next waste processed at ETF.

B.4 Influent Aqueous Waste Sampling and Analysis

The following sections provide a summary of the sampling procedures, frequencies, and analytical parameters for characterization of influent aqueous waste (Section B.2) and in support of the special management requirements for aqueous waste in the LERF and 200 Area ETF (Section B.3).

B.4.1 Sampling Procedures

With a few exceptions, generators are responsible for the characterization, including sampling and analysis, of an influent aqueous waste. Process condensate is either sampled at the 242-A Evaporator or accumulated in a LERF Basin following a 242-A Evaporator campaign and sampled. Other exceptions will be handled on a case-by-case basis and the, LERF and 200 Area ETF Operating Record will be maintained at the unit for inspection by Ecology. The following section discusses the sampling locations, methodologies, and frequencies for these aqueous wastes. For samples collected at the LERF and 200 Area ETF, unit-specific sampling protocol is followed. The sample containers, preservation materials, and holding times for each analysis are listed in Section B.8.

[1]The volume of 150,000 gallons represents two operating volumes of the surge tank.

B.4.1.1 Batch Samples

In those cases where an aqueous waste is sampled in a LERF Basin, samples are collected from risers located in each basin (refer to Section B.1.1), i.e., four separate samples. When LERF levels are low, fewer than four samples can be taken if the sampling approach is still representative and there are no hydraulic lift limitations for drawing a sample to the surface. A hydraulic lift limitation of the sample pump will occur due to the "net positive suction head" requirement for the pump not being met. Operating experience indicates that four samples adequately capture the spatial variability of an aqueous waste stream in the LERF Basin. Specifically, sections of stainless steel (or other compatible material) tubing are inserted into the sample riser to an appropriate depth. Using a portable pump, the sample line is flushed with the aqueous waste and the sample collected. The grab sample containers typically are filled for volatile organic compounds (VOC) analysis first, followed by the remainder of the sample containers for the other parameters.

Several sample ports are also located at 200 Area ETF, including a valve on the inlet line at 200 Area ETF Surge Tank. The sample port on the Surge Tank inlet line can be used to obtain a LERF Basin sample, after which the LERF Basin waste in the Surge Tank can be returned to LERF or processed/stored at ETF. All samples obtained at the LERF or 200 Area ETF are collected in a manner consistent with SW-846 procedures (EPA as amended).

B.4.2 Analytical Rationale

As stated previously, each generator is responsible for designating and characterizing an aqueous waste stream. Accordingly, each generator samples and analyzes an influent waste stream using the target list of parameters (Table B-4) for the waste acceptance process. At the discretion of the LERF and 200 Area ETF management, a generator may provide knowledge in lieu of some analyses as discussed in Section B.2.1.1. The LERF and 200 Area ETF personnel will work with the generator to determine which parameters are appropriate for the characterization.

The analytical methods for these parameters are provided in Section B.8. All methods are EPA methods satisfying the requirements of WAC 173-303-110(3). Additional analyses may be required if historical information and knowledge indicate that an influent aqueous waste contains constituents not included in the target list of parameters. For example, if knowledge indicates that an aqueous waste contains a parameter that is regulated by the Groundwater Quality Criteria (WAC 173-200), that parameter(s) would be added to the suite of analyses required for that aqueous waste stream.

The analytical data for the parameters presented in Table B-4, including VOC, Semi-volatile Organic Compound (SVOC), metals, anions, and general chemistry parameters are used to define the physical and chemical properties of the aqueous waste for the following:

- Set operating conditions in the LERF and 200 Area ETF (e.g., to determine operating configuration, refer to Section B.2.2.2).
- Identify concentrations of some constituents which may also interfere with, or foul 200 Area ETF treatment process (e.g., fouling of the RO membranes, refer to Section B.2.2.2).
- Evaluate LERF liner and piping materials compatibility.
- Determine treatability to evaluate if applicable constituents in the treated effluent will meet Discharge Permit and Delisting limits.
- Estimate concentrations of some constituents in the waste generated in the secondary treatment train (i.e., dry powder waste).

Table B-4 Target Parameters for Influent Aqueous Waste Analyses

Volatile Organic Compounds	Semi-volatile Organic Compounds
Acetone	Acetophenone
Acetonitrile	Cresol (o, p, m)
Benzene	Dichloroisopropyl ether (bis [2-chloropropyl] ether)
1-Butanol	Di-n-octyl phthalate
Carbon disulfide	Diphenylamine
Carbon tetrachloride	Hexachlorobenzene
Chloroform	Hexachlorocyclopentadiene
Methylenechloride	Iosophorone
Tetrachloroethylene	Lindane (gamma-BHC)
Tetrahydrofuran	N-nitrosodimethylamine
	Pyridine
	Tributyl phosphate
	2,4,6-Trichlorophenol

Total Metals		Anions
Arsenic	Magnesium	Chloride
Barium	Mercury	Fluoride
Beryllium	Nickel	Nitrate
Cadmium	Potassium	Nitrite
Calcium	Selenium	Phosphate
Chromium	Silicon	Sulfate
Copper	Silver	**General Chemistry Parameters**
Iron	Sodium	Alkalinity
Lead	Vanadium	Ammonia
	Zinc	Carbonate/Bi-carbonate (calculated from Alkalinity)
		Cyanide
		pH
		Total suspended solids
		Total dissolved solids
		Total organic carbon
		Specific conductivity

B.5 Treated Effluent Sampling and Analysis

The treated aqueous waste, or effluent, from 200 Area ETF is collected in three verification tanks before discharge to the SALDS. To determine whether the discharge limits, and the Final Delisting 200 Area ETF criteria are met, the effluent routinely is sampled at the verification tanks. The sampling and analyses performed are described in the following sections.

B.5.1 Rationale for Effluent Analysis Parameter Selection

The parameters measured in the treated effluent are required by the following regulatory documents:

- Delisting criteria from the Final Delisting 200 Area ETF [40 CFR 261, Appendix IX, Table 2 incorporated by reference by WAC 173-303-910(3)].
- Corresponding State Final Delisting issued pursuant to WAC 173-303-910(3).
- Effluent limits from the Discharge Permit Number ST0004500.
- The Final Delisting 200 Area ETF provides two testing regimes for the treated effluent. Initial verification testing is performed when a new influent waste stream is processed through the 200 Area ETF. For each 200 Area ETF influent waste stream, the first generated verification tank must be sampled and analyzed for all delisting constituents and conductivity. Subsequent verification sampling and analysis of all delisting parameters is performed on every 15th tank of that 200 Area ETF influent waste stream. If the concentration of any analyte is found to exceed a Discharge Permit Number ST0004500, enforcement limit or a Delisting criterion, the contents of the verification tank are reprocessed and/or reanalyzed. The next verification tank generated is also sampled for all delisting constituents.

B.5.2 Effluent Sampling Strategy: Methods, Location, Analyses, and Frequency

Effluent sampling methods and locations, the analyses performed, and frequency of sampling are discussed in the following sections.

B.5.2.1 Effluent Sampling Method and Location

Samples of treated effluent are collected and analyzed to verify the treatment process using 200 Area ETF specific sampling protocol. These verification samples are collected at a sampling port on the verification tank recirculation line. Section B.8 presents the sample containers, preservatives, and holding times for each parameter monitored in the effluent.

B.5.2.2 Analyses of Effluent

The parameters required by the current Discharge Permit Number ST0004500, and Final Delisting 200 Area ETF, conditions are presented in Table B-5. The analytical methods and Practical Quantitation Limits (PQLs) associated with each parameter are provided in Section B.8. The methods and PQLs are equivalent to those used in the analysis of influent aqueous waste.

B.5.2.3 Frequency of Sampling

Treated effluent is tested for all parameters listed in Table B-5 on a frequency satisfying the permit conditions of the Discharge Permit Number ST0004500, and the Final Delisting 200 Area ETF. This effluent must meet the Discharge Permit Number ST0004500, and Final Delisting 200 Area ETF limits associated with these parameters. Grab samples are collected from each verification tank.

During operation of 200 Area ETF, if one or more of the constituents exceeds a Delisting criterion, the Delisting conditions require:

- The characterization data and processing strategy of the influent waste stream be reviewed and changed accordingly to ensure the contents of subsequent tanks do not exceed the Delisting criteria.
- The contents of the verification tank are recycled for additional treatment. The contents that are recycled are resampled after treatment to ensure no constituents exceed a Delisting criteria.
- The contents of the following verification tank are sampled for compliance with the Delisting criteria.

- Treated effluent that does not meet Discharge Permit Number ST0004500 is not discharged to the SALDS until the tank has been retreated and/or reanalyzed.

B.6 Effluent Treatment Facility Generated Waste Sampling and Analysis

The wastes discussed in this section include the wastes generated at 200 Area ETF that are managed in the tank and container storage areas of 200 Area ETF. This section describes the characterization of the following secondary waste streams generated within 200 Area ETF:

- Secondary waste generated from the treatment process, including the following waste forms:
  - Dry powder waste.
  - Concentrated brine.
  - Sludge removed from process tanks.
  - Steam Stripper System concentrator condensate (acetonitrile distillate).
- Waste generated by operations and maintenance activities.
- Miscellaneous waste generated within 200 Area ETF.

For each waste stream described, a characterization methodology and rationale are provided, and sampling requirements are addressed.

B.6.1 Secondary Waste Generated from Treatment Processes

The following terms used in this section, including powder, dry powder, waste powder, and dry waste powder, are equivalent to the term “dry powder waste.” Similarly, terms like concentrate, concentrate waste, slurry, and brine, are equivalent to “brine waste.”

The 200 Area ETF generates secondary waste from the primary and secondary treatment trains. The secondary waste is either a dry powder or concentrate tank slurry (brine) waste. To generate this secondary waste, the primary treatment train waste is received in the secondary treatment train in waste receiving tanks where it is fed into an evaporator. Concentrate waste from the evaporator is then fed to a concentrate tank. From the concentrate tanks, there are two alternatives for treatment of the concentrate waste: either the thin film dryer or the brine loadout system.

If the waste is fed to the thin film dryer, the waste is dried into a powder, and collected into containers. The containers are filled via a remotely controlled system. The condensed overheads from the evaporator and thin film dryer are returned to the surge tank to be fed to the primary treatment train.

If the waste is fed to the brine loadout system, the brine waste is transferred to brine storage tanks or containerized into totes. Totes are filled using the brine loadout system. The containers holding the aqueous brine waste are stored and transferred to an authorized dangerous waste facility for additional treatment. Brine waste can also be transferred to the brine storage tanks for interim storage. Refer to Addendum C, “Process Information,” Section C.2.4 for additional detail.

Occasionally, salts from the treatment process (e.g., calcium sulfate and magnesium hydroxide) accumulate in process tanks as sludge. The sludge is removed and placed in containers. The sludge is dewatered and the supernate is pumped back to 200 Area ETF for treatment.

The secondary treatment system typically receives and processes the following by-products generated from the primary treatment train:

- Concentrate from the first RO stage.
- Backwash and cleaning concentrate from the rough and fine filters.
- Regeneration waste from the ion exchange system.
- Spillage or overflow collected in the process sumps.

In an alternate operating scenario, some aqueous wastes may be fed to the secondary treatment train before the primary treatment train.

Acetonitrile distillate waste from the primary treatment train is generated from operation of the steam strippers. This waste stream is condensate from the stream stripper overheads. Acetonitrile distillate is transferred to storage tanks and can be containerized into totes within the 2025EI Acetonitrile Distillate Load-Out Facility This waste stream will be transferred to an authorized dangerous waste facility for additional treatment.

B.6.1.1 Special Requirements Pertaining to Land Disposal Restrictions

Containers of 200 Area ETF secondary waste are transferred to a treatment, storage or final disposal unit, as appropriate (e.g., the Central Waste Complex or to the ERDF). 200 Area ETF personnel provide the analytical characterization data and necessary knowledge for the waste to be managed by the receiving staff, and for the appropriate LDR documentation.

The following information on the secondary waste is included on the LDR documentation provided to the receiving unit:

- Dangerous waste numbers (as applicable).
- Determination on whether the waste is restricted from land disposal according to the requirements of 40 CFR 268 incorporated by reference by WAC 173-303-140 (i.e., the LDR status of the waste).

The waste tracking information associated with the transfer of waste:

- Waste analysis results.

B.6.1.2 Sampling Methods

Secondary waste is accumulated and chemically adjusted in the concentrate tanks before being fed to the thin film dryer or loaded into containers. The concentrate tanks have agitators for mixing of liquid and suspended solids that may be present. The agitators will be operated during sampling when suspended solids are expected to be present. This ensures all powder waste drums or brine waste containers will be uniform, eliminating the need for multiple samples or spatial sampling equipment.

The dry powder waste and containerized sludge are sampled from containers using the principles presented in SW-846 (EPA as amended) and American Society for Testing Materials (ASTM) Methods, such as those referenced in WAC 173-303-110(2). Sampling methods are discussed in Section B.7.3.1. Methods include, but are not limited to, scoop and thief sampling. The sample container requirements, sample preservation requirements, and maximum holding times for each of the parameters analyzed in either matrix are presented in Section B.8.

Concentrate tank waste samples are collected from recirculation lines. The protocol for concentrate tank sampling prescribes opening a sample port in the recirculation line to collect samples directly into sample containers. The sample port line is flushed before collecting a grab sample. In some cases, it is necessary to sample brine waste in containers after filling. These containers are sampled using American Society for Testing and Materials (ATSM) Methods, such as those referenced in WAC 173-303-110(2). Sampling is performed using a thief sampler or peristaltic sample pump. When using a peristaltic pump, the sample tubing is flushed before collecting a grab sample.

The VOC sampling typically is performed first for grab samples. Each VOC sample container will be filled such that cavitation at the sample valve is minimized and the container has no headspace. The remainder of the containers for the other parameters will be filled next.

Acetonitrile distillate tank waste samples are collected from recirculation lines. The protocol for acetonitrile distillate tank sampling prescribes opening a sample port in the recirculation line to collect samples directly into sample containers. The sample port line is flushed before collecting a grab sample. In some cases, it is necessary to sample acetonitrile distillate waste in containers after filling. These containers are sampled using ATSM Methods, such as those referenced in WAC 173-303-110(2). Sampling is performed using a thief sampler or peristaltic sample pump. When using a peristaltic pump, the sample tubing is flushed before collecting a grab sample.

Table B-5 Rationale for Parameters to be Monitored in Treated Effluent

Parameter	(CAS No.)	Final Delisting 200 Area ETF Delisting[1]	ST0004500 Discharge Permit[2] Effluent Limit
Volatile Organic Compounds			
Acetone	(67-64-1)	X	X
Acetonitrile	(75-05-8)	X	
Benzene	(71-43-2)	X	X
1-Butanol	(71-36-3)	X	
Carbon disulfide	(75-15-0)	X	
Carbon tetrachloride	(56-23-5)	X	X
Chloroform	(67-66-3)		X
Methylene Chloride	(75-09-2)		M
Tetrachloroethylene	(127-18-4)		X
Tetrahydrofuran	(109-99-9)	X	X
Semi-volatile Organic Compounds			
Acetophenone	(98-86-2)		X
Carbazole	(86-74-8)	X	
p-Chloroaniline	(106-47-8)	X	
Chrysene	(218-01-9)	X	
Cresol (total)	(1319-77-3)	X	
Dichloroisopropyl ether (bis [2-chloroisopropyl] ether)	(108-60-1)	X	
Di-n-octyl phthalate	(117-84-0)	X	
Diphenylamine	(122-39-4)	X	
Hexachlorobenzene	(118-74-1)	X	
Hexachlorocyclopentadiene	(77-47-4)	X	
Isophorone	(78-59-1)	X	
Lindane (gamma-BHC)	(58-89-9)	X	
N-nitrosodimethylamine	(62-75-9)	X	X

Table B-5 Rationale for Parameters to be Monitored in Treated Effluent

Parameter	(CAS No.)	Final Delisting 200 Area ETF Delisting[1]	ST0004500 Discharge Permit[2] Effluent Limit
Pyridine	(110-86-1)	X	
Tributyl phosphate	(126-73-8)	X	
2,4,6-Trichlorophenol	(88-06-2)	X	
Polychlorinated Biphenyls			
Aroclor 1016	(12674-11-2)	X	
Aroclor 1221	(11104-28-2)	X	
Aroclor 1232	(11141-16-5)	X	
Aroclor 1242	(53469-21-9)	X	
Aroclor 1248	(12672-29-6)	X	
Aroclor 1254	(11097-69-1)	X	
Aroclor 1260	(11096-82-5)	X	
Total Metals[3]			
Arsenic	(7440-38-2)	X	X
Barium	(7440-39-3)	X	
Beryllium	(7740-41-7)	X	X
Cadmium	(7440-43-9)	X	X
Chromium	(7440-47-3)	X	X
Copper	(7440-50-8)		X
Lead	(7439-92-1)	X	X
Mercury	(7439-97-6)	X	X
Nickel	(7440-02-0)	X	
Selenium	(7782-49-2)	X	
Silver	(7440-22-4)	X	
Vanadium	(7440-62-2)	X	
Zinc	(7440-66-6)	X	
Anions			
Chloride	(16887-00-6)		X
Fluoride	(16984-48-8)	X	
Nitrate (as N)	(14797-55-8)		X
Nitrite (as N)	(1479765-0)		X
Sulfate	(14808-79-8)		X
Other Analyses			
Ammonia	(7664-41-7)	X	X
Cyanide	(57-12-5)	X	

Table B-5 Rationale for Parameters to be Monitored in Treated Effluent

Parameter	(CAS No.)	Final Delisting 200 Area ETF Delisting[1]	ST0004500 Discharge Permit[2]
			Effluent Limit
Total dissolved solids			X
Total organic carbon			X
Total suspended solids			X
Specific conductivity			M

[1]Parameters required by the current conditions of the Final Delisting 200 Area ETF, 40 CFR 261, Appendix IX, Table 2 incorporated by reference by WAC 173 303 910(3), 86 Federal Register 50647 (EPA September 10, 2021).

[2]Parameters required by the current conditions of the Discharge Permit Number ST0004500.

[3]Metals reported as total concentrations.

X = Rationale for measuring this parameter in treated effluent.

M = Monitor only; no limit defined.

B.6.1.3 Sampling Frequency

When designation or identification of applicable LDR treatment standards of the 200 Area ETF secondary waste cannot be based on influent characterization data or knowledge as described in Section B.6.1.1, 200 Area ETF secondary waste is sampled on a batch basis. A batch is defined as any volume of aqueous waste that is being treated under consistent and constant process conditions.

When personnel exposures are of concern, one representative sample will be collected from the concentrate tank. A representative sample of the influent may be taken as an alternative, if the waste from the Concentrate Tank also poses an exposure concern. The sample will be analyzed for the appropriate parameters identified in Table B-6 based on the needs identified from evaluating influent waste analysis data. If sampling of the concentrate tank is not technically practicable for purposes of designating the powder, direct sampling of the dry powder will be used to make determinations on the dry powder. The dry powder or concentrate tanks will be resampled in the following situations:

- Change in influent characterization.
- Change in process chemistry, as indicated by in-line monitoring of conductivity and pH.
- The LERF and 200 Area ETF management have been notified, or have reason to believe that the process generating the waste has changed (for example, a source change such as a change in the well-head for groundwater that significantly changes the aqueous waste characterization).
- The LERF and 200 Area ETF management note an increase or decrease in the concentration of a constituent in an aqueous waste stream, beyond the range of concentrations that was described or predicted in the waste characterization.

B.6.2 Operations and Maintenance Waste Generated at the 200 Area Effluent Treatment Facility

Operation and maintenance of process and ancillary equipment generates additional routine waste. These waste materials are segregated to ensure proper handling and disposition, and to minimize the commingling of potentially dangerous waste with non-dangerous waste. The following waste streams are anticipated to be generated during routine operation and maintenance of 200 Area ETF. This waste might or might not be dangerous waste, depending on the nature of the material and its exposure to a dangerous waste.

- Spent lubricating oils and paint waste from pumps, the dryer rotor, compressors, blowers, and general maintenance activities.
- Spent filter media and process filters.
- Spent ion exchange resin.
- High Efficiency Particulate Air (HEPA) filters.
- UV light tubes.
- RO membranes.
- Equipment that cannot be returned to service.
- Other miscellaneous waste that might contact a dangerous waste (e.g., plastic sheeting, glass, rags, paper, waste solvent, or aerosol cans).

These waste streams are stored at 200 Area ETF before being transferred for final treatment, storage, or disposal as appropriate.

This waste is characterized and designated using knowledge (from previously determined influent aqueous waste composition information); analytical data; and Safety Data Sheet (SDS)/Material Safety Data Sheets (MSDS) of the chemical products present in the waste or used (the data sheets are maintained at 200 Area ETF). Sampling of these waste streams is not anticipated; however, if an unidentified or unlabeled waste is discovered, that waste is sampled. This "unknown" waste is sampled and analyzed for the parameters in Table B-6 as appropriate, and will be designated according to WAC 173-303-070. The specific analytical methods for these analyses are provided in Section B.8.

B.6.3 Other Waste Generated at the 200 Area Effluent Treatment Facility

There are two other potential sources of waste at 200 Area ETF: spills and/or overflows, and discarded chemical products. Spills may be subject to the requirements of Permit Condition II.E. Spilled material that potentially might be dangerous waste generally is either containerized or routed to 200 Area ETF sumps where the material is transferred either to the surge tank for treatment or to the secondary treatment train. In most cases, knowledge and the use of SDS/MSDS are sufficient to designate the waste material. If the source of the spilled material is unknown and the material cannot be routed to 200 Area ETF sumps, a sample of the waste is collected and analyzed according to Table B-6, as necessary, for appropriate characterization of the waste. Unknown wastes will be designated according to WAC 173-303-070. The specific analytical methods for these analyses are provided in Section B.8.

A discarded chemical product waste stream could be generated if process chemicals, cleaning agents, or maintenance products become contaminated or are otherwise rendered unusable. In all cases, these materials are appropriately containerized and designated. Sampling is performed, as appropriate, for waste designation.

Table B-6 200 Area Effluent Treatment Facility Generated Waste - Sampling and Analysis

Parameter[1]	Rationale
• Total solids or percent water[2].	• Calculate dry weight concentrations.
• VOCs[3].	• LDR - verify treatment standards.
• SVOCs[3].	• LDR - verify treatment standards.
• Metals (arsenic, barium, cadmium, chromium, lead, mercury, selenium, silver).	• Waste designation. • LDR - verify treatment standards.

Table B-6 200 Area Effluent Treatment Facility Generated Waste - Sampling and Analysis

Parameter[1]	Rationale
• Cation and anions of concern.	• Address receiving TSD unit waste acceptance requirements.
• pH.	• Waste designation.

[1]For influent and concentrate tank samples, the total sample (solid plus liquid) is analyzed and the analytical result is expressed on a dry weight basis. The result for toxicity characteristic metal and organic is divided by a factor of 20 and compared to the toxicity characteristic (TC) constituent limits [WAC 173-303-090(8)]. If the TC limit is met or exceeded, the waste is designated accordingly. All measured parameters are compared against the corresponding treatment standards.

[2]Total solids or percent water are not determined for unknown waste and dry powder waste samples and are analyzed in maintenance waste and sludge samples, as appropriate (i.e., percent water might not be required for such routine maintenance waste as aerosol cans, fluorescent tubes, waste oils, batteries, etc., or sludge that has dried).

[3]VOC and/or SVOC analysis of secondary waste is required unless influent characterization data and knowledge indicate that the constituent will not be in the final secondary waste at or above the LDR.

B.7 Quality Assurance/Quality Control

The following QA/QC plan for LERF and 200 Area ETF is provided as required by WAC 173-303-810(6) and follows the guidelines of EPA QA/G-5.

B.7.1 Project Management

The following sections address project administrative functions and approaches.

B.7.1.1 Project Organization

Overall management of the LERF and 200 Area ETF is performed by the Facility Manager, who is responsible for safe operation of the facility, including implementation of this QA/QC plan and compliance with applicable permits and regulations. The Facility Manager also provides retention of project records in accordance with this plan. Assisting the Facility Manager is an Environmental Field Representative that monitors compliance, reviews new requirements and regulations, and interfaces with EPA and Ecology. Also assisting the Facility Manager is a QA representative who is responsible for implementing the QA program at the facility.

Reporting to the Facility Manager are several support groups. The Operations group consists of trained personnel who operate the plant, including operators performing sampling activities such as collection, packaging, and transportation of samples to the laboratory. The Maintenance group is responsible for performing calibrations and preventative maintenance on facility equipment, including pH, conductivity, and flow meters required by environmental permits. The Engineering group monitors the process with online instruments and sampling for process control. The Engineering group also performs waste acceptance, and environmental compliance activities, including scheduling sampling, generating data forms, and reviewing data.

B.7.1.2 Special Training

Individuals involved in sampling, analysis, and data review will be trained and qualified to implement safely the activities addressed in this WAP and QA/QC plan. Training will conform to the training requirements specified in WAC 173-303-330 and Addendum G, “Personnel Training.” Training records will be maintained in accordance with Section B.7.1.3.

B.7.1.3 Documentation and Records

Sample records are documented as part of the LERF and 200 Area ETF Operating Record pursuant to Permit Condition II.I. These documents and records include the following:

- Training.
- Chains-of-Custody for all regulatory sampling performed by LERF and 200 Area ETF.
- Data Summary Reports.
- QA/QC reports.
- Assessment reports.
- Instrument inspection, maintenance, and calibration logs.

B.7.2 Data Quality Parameters and Criteria

Data quality parameters are listed by EPA QA/G-5S, *Guidance for Choosing a Sampling Design for Environmental Data Collection* as:

- Purpose of Data Collection (e.g., determining if a parameter exceeds a threshold level).
- Spatial and Temporal Boundaries of Study.
- Preliminary Estimation of Sample Support (volume that each sample represents).
- Statistical Parameter of Interest (e.g., mean, percentile, percentage).
- Limits on Decision Error/Precision (e.g., false acceptance error, false rejection error).

The parameters for the first four bullets (limits, sample points, frequency of samples, etc.) are already established in the permits, delisting petition, and this WAP. The focus of this QA/QC plan is on limits on decision error/precision.

The data quality parameters were chosen to ensure Limits on Decision Error/Precision are appropriate for purposes of using the data to demonstrate compliance with permits, delisting exclusion limits, and this WAP. The principal quality parameters are precision, accuracy, representativeness, comparability, and completeness. Secondary data parameters of importance include sensitivity and detection levels. The data quality parameters and the data acceptance criteria are discussed below.

B.7.2.1 Precision

Precision is a measure of agreement among replicate measurements of the same property, under prescribed similar conditions. Precision is expressed in terms of the relative percent difference (RPD) for duplicate measurements. QA/QC sample types that test precision include field and laboratory duplicates and spike duplicates. The RPDs for laboratory duplicates and/or matrix spike duplicates will be routinely calculated.

$$\text{RPD} = (100)absolute\ value\ of\left(\frac{\text{sample result} - \text{duplicate sample result}}{\text{average of sample result} + \text{duplicate sample result}}\right)$$

Matrix spike duplicates are replicates of matrix spike samples that are analyzed with every analytical batch that contains a 200 Area ETF treated effluent sample. The precision of the analytical methods are estimated from the results of the Matrix Spike (MS) and the Matrix Spike Duplicate (MSD) for selected analytes. Matrix spike analyses cannot be performed for certain analytical methods, including conductivity, pH, and total dissolved solids. Duplicate analyses are used to determine the RPD for these methods. The precision acceptance criteria are specified in Table B-7.

B.7.2.2 Accuracy

Accuracy assesses the closeness of the measured value to an accepted reference value. Accuracy of analytical results is typically assessed using matrix spikes. A matrix spike is the addition of a known amount of the analyte to the sample matrix being analyzed. Accuracy is expressed as a percent recovery of the spiked samples.

$$\text{Percent Recovery} = 100\left(\frac{\text{matrix spike sample result} - \text{sample result}}{\text{spiked amount}}\right)$$

Matrix spike analyses cannot be performed on certain analytical methods, including conductivity, pH, and total dissolved solids. The percent recovery for the laboratory control standard samples demonstrates that these methods are working properly and gives an estimate of the method's accuracy. The percent recovery will be routinely calculated.

Accuracy criteria are established to provide confidence that the result is below the action level. Therefore the closer the result is to the action level the higher the degree of accuracy needed. The upper and lower accuracy acceptance criteria are specified in Table B-7. The criteria are reasonable values based on previous analysis of constituents in the delisting exclusion, or similar constituents.

B.7.2.3 Representativeness

Representativeness expresses the degree to which data accurately and precisely represent selected characteristics of a parameter at a sampling point or process condition. Because of the matrix being analyzed, dilute aqueous solution, it is not expected that representativeness will be of concern, except when there are potential for changes to process conditions such as the facility influent concentrations or waste processing strategy. Sampling due to these changes in process conditions is addressed in Section B.6.1.3.

The representativeness of a sample may be compromised by the presence of contaminants introduced in the field or the laboratory. To determine if contamination may be present, a blank sample of reagent water is analyzed. A method blank is performed by the laboratory on every batch of 20 samples being analyzed at the same time. The presence of a constituent in the sample and the blank sample indicates contamination has occurred.

B.7.2.4 Completeness

Completeness is a measure of the amount of valid data obtained from a measurement system, expressed as a percentage of the number of valid measurements that were planned to be collected. Lack of completeness is sometimes caused by loss of a sample, loss of data, or inability to collect the planned number of samples. Incompleteness also occurs when data are discarded because they are of unknown or unacceptable quality. Since most regulatory sampling events performed by LERF and 200 Area ETF involve a single sample, all analysis must be complete and valid.

B.7.2.5 Comparability

Comparability is the confidence with which one data set can be compared to another. Comparability is achieved by using sampling and analytical techniques, which provide for measurements that are consistent and representative of the media and conditions measured. In laboratory analysis, the term comparability focuses on method type, holding times, stability issues, and aspects of overall analytical quantitation.

B.7.2.6 Sensitivity and Detection Levels

Sensitivity is the measure of the concentration at which an analytical method can positively identify and report analytical results. Sensitivity represents the maximum value for a detection level that will reasonably assure the results are below the established limits. The analytical method selected by LERF and 200 Area ETF should have a detection level for each constituent that is below the sensitivity. The preferred detection level is the PQL, which is lowest concentration that can be reliably measured during routine laboratory conditions. If the method PQL cannot meet the sensitivity for some constituents, the minimum concentration or attribute that can be measured by a method (method detection limit) or by an instrument (instrument detection limit) may be used. The sensitivity levels, specified in Table B-7, are derived from the delisting limits, water discharge limits, and uncertainty values, which are based on the required precision and accuracy for each constituent.

B.7.3 Data Generation and Acquisition

The following section addresses QA requirements for data generation and acquisition.

B.7.3.1 Sampling Method

LERF and 200 Area ETF samples required by the permits and delisting are collected as grab samples. Sampling for the purpose of waste designation of secondary waste is performed using grab, composite, thief, scoop, or Composite Liquid Waste Sampler (COLIWASA). The selection of the sample collection device depends on the type of sample, the sample container, the sampling location, and the nature and distribution of the waste components. In general, the methodologies used for specific materials correspond to those referenced to WAC 173-303-110(2). The selection and use of the sampling device is supervised or performed by a person thoroughly familiar with the sampling requirements.

The following protocol applies to all sampling methods:

- All containers will be filled within as short a time period as reasonably achievable.
- Volatile Organic Analysis (VOA) sample containers will be filled first, and prior to any subdividing of a composited sample.
- VOA samples consisting of a set of two or more sample containers will be filled sequentially. The sample containers are considered equivalent and given identical sampling times.
- All VOA sample containers must have no headspace and be free of trapped air bubbles.
- Grab sample protocol includes:
  - Sample lines should be as short as reasonably achievable and free of traps and pockets in which solids might settle.
  - The sample line should be flushed before sampling with a minimum volume equivalent to three times the sample line volume.
  - Contamination to the sample from contact with the internal and external surfaces of the tap should be minimized.

Thief and COLIWASA samplers are used to sample liquid waste containers such as drums. Scoop samplers are used to sample powder waste generated in the thin-film dryer. Sample requirements for these samples include:

- Thief or COLIWASA sampler, the sampler should be lowered into the liquid slowly so the level of the liquid inside and outside the sampler tube remain about the same.
- When lifting the thief or COLIWASA sampler from the solution, the outside should be wiped down, or the excess water allowed to drip off, before filling the sample container.

B.7.3.2 Sample Handling, Custody, and Shipping

The proper handling of sample bottles after sampling is important to ensure the samples are free of contamination and to demonstrate the samples have not been tampered with.

B.7.3.2.1 Chain-of-Custody

Evidence of collection, shipment, receipt at the laboratory, and laboratory custody until disposal will be documented using a Chain-of-Custody (COC) form. The COC form will, as a minimum identify sample identification number, sampling date and time, sampling location, sample bottle type and number, analyses to be performed, and preservation method.

The operations person who signs as the collector on the COC is the first custodian of the samples. A custodian must maintain continuous custody of sample containers at all times from the time the sample is taken until delivery to the laboratory or until delivery to a common carrier for shipment to an off-site location. Custody is maintained by any of the following:

- The custodian has the samples in view, or has placed the samples in locked storage, or keeps the samples within a secured area (e.g., controlled by authorized personnel only), or has applied a tamper-indicating device, such as evidence tape, to the sample containers or shipping containers.
- The custodian has taken physical possession of the samples or the shipping containers sealed with an intact tamper-indicating device, such as evidence tape.

B.7.3.2.2 Sample Preservation, Containers, and Holding Time

Table B-7 lists the sample container, preservation method, and holding time requirements for different types of analyses. These parameters are based on the requirements of 40 CFR 136, Table II.

B.7.3.3 Instrument Calibration and Preventive Maintenance

LERF and 200 Area ETF uses instruments to monitor operations and meet regulatory requirements. This includes continuous pH and conductivity monitors required by facility permits and delisting. All instruments are calibrated according to frequencies and tolerances established by the LERF and 200 Area ETF engineering group. Calibrations and other maintenance actions are scheduled and tracked by LERF and 200 Area ETF maintenance group using a preventive maintenance database. Measuring and test equipment used for instrument calibration is controlled, calibrated at specified intervals, and maintained to establish accuracy limits.

B.7.4 Assessment and Oversight

Quality programs can only be effective if meaningful assessments are performed to monitor and respond to issues associated with program performance. Routine assessment of data is performed as part of the validation process discussed in Section B.7.5.1.

B.7.4.1 Assessments and Response

Management assessments are conducted by first line management and subject matter experts, focusing on procedural adequacy, compliance, and overall effectiveness of the program. Management assessments of the sample program typically include the LERF and 200 Area ETF QA representative. Each management assessment has a performance objective or lines of inquiry. Examples may include personnel training, proper performance of sample custody, or completeness of sampling records.

B.7.4.2 Reports to Management

Results of performance assessments, including any issues identified, are provided to the LERF and 200 Area ETF Facility Manager in a written report. The Facility Manager is responsible to correct all findings from the report.

B.7.5 Verification and Validation of Analytical Data

The data verification and validation processes will ensure that the data resulting from the selected analytical method are consistent with requirements specified in this QA/QC plan.

B.7.5.1 Data Verification

The primary data reporting will be by electronic data systems. Data verification will be performed on laboratory data packages that support environmental compliance to ensure that their content is complete and in order. A review of the data package will be performed to ensure that:

- The data package contains the required technical information.
- Deficiencies are identified and documented.
- Identified deficiencies are corrected by the laboratory and the appropriate revisions are made.
- Deficient pages are replaced with the laboratory corrections.
- A copy of the completed verification report is placed in the data file.

B.7.5.2 Data Validation

Data validation ensures that the data resulting from analytical measurements meet the quality requirements specified in the QA/QC plan. Data validation will be performed on data packages that support environmental compliance.

The following are included in data validation:

- COC - Verify the COC shows unbroken custody from sampling through receipt at the laboratory.
- Request analysis - Review the sample results to verify the requested analysis was performed. If an alternate method was used, verify permit-required detection limits were met.
- Holding times - Review the sample results to verify the analyses were performed within required holing times and where applicable, extraction times.
- Blank - Review the results of trip, field, and equipment blank samples to verify the sample results are not compromised by contamination.
- Laboratory QC - Verify the laboratory QC was completed and there are no outstanding problems.

B.8 Analytical Methods, Sample Containers, Preservative Methods, and Holding Times

Table B-7 Sample and Analysis Criteria for Influent Aqueous Waste and Treated Effluent

Parameter	Analytical Method[1]	Method Practical Quantitation Limits Sensitivity[2]	Accuracy/ Precision for Method[3] (Percent)	Sample Container[4]/ Preservative[4]/ Holding Time[5]
Volatile Organic Compounds				
Acetone	SW-846 8260 or EPA-600 624	40	60-120 / 20	Sample container 3 x 40-mL amber glass with septum Preservative HCl to pH<2; 4°C Holding time 14 days

Table B-7 Sample and Analysis Criteria for Influent Aqueous Waste and Treated Effluent

Parameter	Analytical Method[1]	Method Practical Quantitation Limits Sensitivity[2]	Accuracy/ Precision for Method[3] (Percent)	Sample Container[4]/ Preservative[4]/ Holding Time[5]
Acetonitrile		820	60-120 / 20	
Benzene		5	60-120 / 20	
1-Butanol		1600	60-120 / 20	
Carbon disulfide		1500	60-120 / 20	
Carbon tetrachloride		5	60-120 / 20	
Chloroform		5	50-130 / 20	
Methylene chloride		5	50-150 / 20	
Tetrachloroethylene		5	65-140 / 20	
Tetrahydrofuran		100	60-120 / 20	
Semi-volatile Organic Compounds				
Acetophenone	SW-846 8270 or EPA-600 625	10	70-110 / 25	Sample container 4 x 1-liter amber glass Preservative 4°C Holding time 7 days for extraction; 40 days for analysis after extraction
Carbazole		110	50-120 / 25	
p-Chloroaniline		76	50-120 / 25	
Chrysene		350	50-120 / 25	
Cresol (o, p, m)		760	50-120 / 25	
Di-n-octyl phthalate		300	50-120 / 25	
Diphenylamine		350	50-120 / 25	
Hexachlorobenzene		2	50-120 / 25	
Hexachlorocyclopentadiene		110	50-120 / 25	
Isophorone		2600	50-120 / 25	
Lindane (gamma-BHC)		1.9	50-120 / 25	
N-nitrosodimethylamine		12	50-120 / 25	
Pyridine		15	50-120 / 25	
Tributyl phosphate		76	50-120 / 25	
2.4.6-Trichlorophenol		230	50-120 / 25	

Table B-7 Sample and Analysis Criteria for Influent Aqueous Waste and Treated Effluent

Parameter	Analytical Method[1]	Method Practical Quantitation Limits Sensitivity[2]	Accuracy/ Precision for Method[3] (Percent)	Sample Container[4]/ Preservative[4]/ Holding Time[5]
Polychlorinated Biphenyls				
Aroclor-1016	SW-846 8082	0.4	50-110 / 25	Sample container 4 x 1-liter amber glass Preservative 4°C Holding time 1 year for extraction; 1 year for analysis after extraction
Aroclor-1221		0.4	50-110 / 25	
Aroclor-1232		0.4	50-110 / 25	
Aroclor-1242		0.4	50-110 / 25	
Aroclor-1248		0.4	50-110 / 25	
Aroclor-1254		0.4	50-110 / 25	
Aroclor-1260		0.4	50-110 / 25	
Total Metals				
Arsenic	EPA-600 200.8	11	70-130 / 20	Sample container 1 x 0.5-liter plastic/glass Preservative 1:1 HNO_3 to pH<2 Holding time 180 days; mercury 28 days
Beryllium		34	75-125 / 20	
Cadmium		5	70-130 / 20	
Chromium		20	70-130 / 20	
Copper		70	70-130 / 20	
Lead		10	70-130 / 20	
Selenium		20	70-130 / 20	
Barium	SW-846 6010/ EPA-600 200.7	1200	75-125 / 20	
Calcium		200	75-125 / 20	
Iron		100	75-125 / 20	
Magnesium		400	75-125 / 20	
Nickel		340	75-125 / 20	
Potassium		10,000	75-125 / 20	
Silicon		580	75-125 / 20	

Table B-7 Sample and Analysis Criteria for Influent Aqueous Waste and Treated Effluent

Parameter	Analytical Method[1]	Method Practical Quantitation Limits Sensitivity[2]	Accuracy/ Precision for Method[3] (Percent)	Sample Container[4]/ Preservative[4]/ Holding Time[5]
Silver		83	75-125 / 20	
Sodium		2500	75-125 / 20	
Vanadium		120	75-125 / 20	
Zinc		5100	75-125 / 20	
Mercury	SW-846 7470, or EPA-600 245.1	2	70-130 / 20	
General Chemistry				
Chloride	EPA-600 300.0	1000	70-130 / 20	Sample container 1 x 60-mL plastic/glass Preservative 4°C Holding time 28 days; nitrate and nitrite 48 hours
Fluoride		880	70-130 / 20	
Formate		1250	70-130	
Nitrate (as N)		100	70-130 / 20	
Nitrite (as N)		100	70-130 / 20	
Phosphate		1500	70-130 / 20	
Sulfate		10,000	70-130 / 20	
Ammonia (as N)	EPA-600, 300.7, or EPA-600 350.1	40	70-130 / 20	Sample container 1 x 50-mL glass or plastic Preservative H_2SO_4 to pH<2; 4°C Holding time 28 days
Cyanide	EPA-600 335.2/335.3	350	70-130 / 20	Sample container 1 x 250-mL glass or plastic Preservative NaOH to pH>12; 4°C Holding time 14 days

Table B-7 Sample and Analysis Criteria for Influent Aqueous Waste and Treated Effluent

Parameter	Analytical Method[1]	Method Practical Quantitation Limits Sensitivity[2]	Accuracy/ Precision for Method[3] (Percent)	Sample Container[4]/ Preservative[4]/ Holding Time[5]
Alkalinity (used to calculate carbonate/bicarbonate)	EPA-600 310.1/310.2	ND	ND	Sample container 1 x 50-mL glass or plastic Preservative 4°C Holding time 14 days
Total dissolved solids	EPA-600 160.1 or SM2540C	ND	ND	Sample container 1 x 500-mL glass or plastic Preservative 4°C Holding time 7 days
Total suspended solids	EPA-600 160.2 or SM2540D	ND	ND	Sample container 1 x 1-L glass or plastic Preservative 4°C Holding time 7 days
Specific conductivity	EPA-600 120.1 (in lab) or SM2510B	ND	ND	Sample container 1 x 50-mL glass or plastic Preservative 4°C Holding time 28 days
pH[6]	EPA-600 150.1 or SM4500-H^+B	ND	ND	Sample container 1 x 60-mL glass or plastic Preservative None Holding time Analyze immediately

Table B-7 Sample and Analysis Criteria for Influent Aqueous Waste and Treated Effluent

Parameter	Analytical Method[1]	Method Practical Quantitation Limits Sensitivity[2]	Accuracy/ Precision for Method[3] (Percent)	Sample Container[4]/ Preservative[4]/ Holding Time[5]
Total organic carbon	SW-846 9060 or SMC5310	ND	ND	Sample container 1 x 250-mL amber glass Preservative H_2SO_4 to pH<2; 4°C Holding time 28 days

[1]SW-846 or EPA-600 methods are presented unless otherwise noted. Other methods might be substituted if the applicable PQL can be met.

[2]ST0004500 required method PQL or Delisting Exclusion condition 2 report sensitivity/detection level, whichever is lower. Units are parts per billion unless otherwise noted.

[3]Accuracy/precision used to confirm or reestablish MDL.

[4]Sample bottle, volumes, and preservatives could be adjusted, as applicable, for safety reasons.

[5]Holding time = time between sampling and analysis.

[6]pH monitored in influent aqueous waste only.

N/A = Not applicable.

ND = Not determined.

MDL = Method detection level.

RL = Reporting limit.

1

Table B-8 Sample Containers, Preservative Methods, and Holding Times for 200 Area Effluent Treatment Facility Generated Waste

Parameter	Analytical Method[1]	Method Practical Quantitation Limits	Accuracy/ Precision for Method (Percent)	Sample Container[2]/ Preservative[2]/ Holding Time[3]
Liquid Matrix				
For methods other than total solids, analyze using the methods and QA/QC in Table B-7. For each method, analyze the target compound list.				
Total solids[4]	EPA-600 160.3	ND	ND	Sample container 1 x 500-mL glass or plastic Preservative – 4°C Holding time – 7 days
Solid Matrix				
VOCs (combined method target compound lists)	SW-846 8260	Refer to Table B-7	Refer to Table B-7	Sample container 1 x 40-mL amber glass with septum Preservative – 4°C Holding time – 14 days

Table B-8 Sample Containers, Preservative Methods, and Holding Times for 200 Area Effluent Treatment Facility Generated Waste

Parameter	Analytical Method[1]	Method Practical Quantitation Limits	Accuracy/ Precision for Method (Percent)	Sample Container[2]/ Preservative[2]/ Holding Time[3]
SVOCs (method target compound list)	SW-846 8270	Refer to Table B-7	Refer to Table B-7	Sample container 1 x 125-mL amber glass Preservative – 4°C Holding time – 14 days for extraction; 40 days for analysis after extraction.
Polychlorinated Biphenyls (method target compound list)	SW-846 8082	Refer to Table B-7	Refer to Table B-7	Sample container Amber glass – 50 g of sample Preservative – 4°C Holding time – 1 year for extraction; 1 year for analysis after extraction.
RCRA Metals (method target compound list)	EPA-600 200.8	Refer to Table B-7	Refer to Table B-7	Sample container Glass or plastic – 10 g of sample Preservative – none, mercury 4°C Holding time – 180 days; mercury 28 days.
Total Metals (method target compound list)	SW-846 6010	Refer to Table B-7	Refer to Table B-7	
Anions (method target compound list)	EPA-600 300.0	Refer to Table B-7	Refer to Table B-7	Sample container Glass or plastic – 25 g of sample Preservative – none Holding time – 6 months for extraction; 28 days for analysis after extraction, nitrate and nitrite 48 hours for analysis after extraction.
Ammonia	EPA-600 300.7	Refer to Table B-7	Refer to Table B-7	Sample container Glass or plastic – 25 g of sample Preservative – none Holding time – 6 months for extraction; 28 days for analysis after extraction.

Table B-8 Sample Containers, Preservative Methods, and Holding Times for 200 Area Effluent Treatment Facility Generated Waste

Parameter	Analytical Method[1]	Method Practical Quantitation Limits	Accuracy/ Precision for Method (Percent)	Sample Container[2]/ Preservative[2]/ Holding Time[3]
pH	SW-846 9045	ND	ND	Sample container Glass or plastic – 50 g of sample Preservative – none Holding time – none
Toxicity Characteristic Leaching Procedure[5]	SW-846 1311	N/A	N/A	Sample container Refer to specific method being performed after TCLP – 125 g of sample. Preservative – None (after TCLP, preserve extract per method being performed). Holding time – Metals: 180 days for TCLP extraction, mercury 28 days for TCLP extraction. Semi-volatile organics analysis (SVOA): 14 days for TCLP extraction (after TCLP, refer to specific methods for time for analysis after extraction).

[1]SW-846 or EPA-600 methods are presented unless otherwise noted. Other methods might be substituted if the applicable PQL can be met.

[2]Sample bottle, volumes, and preservatives could be adjusted, as applicable, for safety reasons.

[3]Holding time equals time between sampling and analysis.

[4]Total dissolved solids and total suspended solids may be performed in place of total solids. The requirements for containers, preservatives, and methods are provided in Table B-7.

[5]Extraction procedure, as applicable; extract analyzed by referenced methods [WAC 173-303-110(3)(c)].

N/A = Not applicable.

ND = Not determined.

TCLP = Toxicity Characteristic Leaching Procedure.

1

This page intentionally left blank.